

### 1.1.2.6. Application of Part 11

(1) Except as provided in Sentence (2), Part 11 of Division B applies to the design and *construction* of existing *buildings*, or parts of existing *buildings*, that have been in existence for at least five years.

(2) If a *building* has been in existence for at least five years but includes an addition that has been in existence for less than five years, Part 11 of Division B applies to the entire *building*.

### 1.1.2.7. Existing Buildings

(1) Except as provided in Section 3.17. of Division B, Section 9.40. of Division B and Part 11 of Division B, if an existing *building* is extended or is subject to material alteration or repair, this Code applies only to the design and *construction* of the extensions and those parts of the *building* that are subject to the material alteration or repair.

(2) If an existing previously occupied *building* is moved from its original location to be installed elsewhere, or is dismantled at its original location and moved to be reconstituted elsewhere, this Code applies only to changes to the design and *construction* of the *building* required as a result of moving the *building*.

## PART 11 RENOVATION

<b>Section</b>	<b>11.1.</b>	<b>General</b>
	<b>11.1.1.</b>	<b>Scope</b>
	<b>11.1.2.</b>	<b>Application</b>
<b>Section</b>	<b>11.2.</b>	<b>Classification of Existing Buildings</b>
	<b>11.2.1.</b>	<b>Classification</b>
<b>Section</b>	<b>11.3.</b>	<b>Proposed Construction</b>
	<b>11.3.1.</b>	<b>New and Existing Building Systems</b>
	<b>11.3.2.</b>	<b>Extension of Buildings</b>
	<b>11.3.3.</b>	<b>Renovation</b>
	<b>11.3.4.</b>	<b>Plumbing</b>
	<b>11.3.5.</b>	<b>Sewage Systems</b>
<b>Section</b>	<b>11.4.</b>	<b>Performance Level Evaluation and Compensating Construction</b>
	<b>11.4.1.</b>	<b>General</b>
	<b>11.4.2.</b>	<b>Reduction in Performance Level</b>
	<b>11.4.3.</b>	<b>Compensating Construction</b>
<b>Section</b>	<b>11.5.</b>	<b>Compliance Alternatives</b>
	<b>11.5.1.</b>	<b>Compliance Alternatives</b>

### Section 11.1. General

#### 11.1.1. Scope

##### 11.1.1.1. Scope

(1) The scope of this Part shall be as described in Subsection 1.1.2. of Division A.

##### 11.1.1.2. Definitions

(1) In this Part,

*Building system* means a combination of elements or components that form a complete major division of *construction* in the design of a *building* or part of a *building*, including a structural or framing system, a waterproofing system,

a *drainage system*, an *exterior cladding system*, a *roofing system*, a *window system*, a *partition system*, a *corridor system*, a *stair system*, a *fire alarm and detection system*, a *sprinkler system* or a *heating, ventilation or air-conditioning system*, a *foundation system*, a *standpipe and hose system*, a *flooring system*, a *plumbing system*, a *sewage system* or an *electrical system*.

## 11.1.2. Application

### 11.1.2.1. Extension, Material Alteration or Repair

(1) Where an existing *building* is subject to extension, material alteration or repair,

(a) the proposed *construction* shall comply with Section 11.3., and

(b) the *performance level* of the *building* shall be evaluated and compensating *construction* shall be undertaken in accordance with Section 11.4.

## Section 11.2. Classification of Existing Buildings

### 11.2.1. Classification

#### 11.2.1.1. Construction Index and Hazard Index

(1) Where proposed *construction* will result in the change of *major occupancy* of all or part of an existing *building* to another *major occupancy*, the *building* shall be classified as to its,

(a) *construction* on the basis of its *construction indexes* provided for in this Part, including Table 11.2.1.1.A., and

(b) *occupancy* on the basis of its *hazard index* as provided for in this Part, including Tables 11.2.1.1.B. to 11.2.1.1.N.

(2) Small or medium sized existing *buildings* as determined in Tables 11.2.1.1.B. to 11.2.1.1.N. facing multiple *streets* may be assigned a *hazard index* credit of 1, which may be subtracted from the *hazard index* of the proposed *major occupancy* to reduce the additional upgrading required by Table 11.4.3.4.A. provided,

- (a) the *building* does not contain a Group B, Division 1, a Group C, or a Group F, Division 1 *occupancy*, and
- (b) firefighting access complying with Articles 3.2.5.1. to 3.2.5.5. or Subsection 9.10.20. is provided.

(3) The requirements of Articles 3.2.2.20. to 3.2.2.83. do not apply to this Part.

#### **11.2.1.2. Multiple Occupancies**

(1) The classification of an existing *building* of multiple *occupancy* under Article 11.2.1.1. shall be applied according to Articles 3.2.2.5. to 3.2.2.8.

#### **11.2.1.3. Prohibition of Occupancy Combinations**

(1) Nothing in this Part relieves an applicant from complying with the requirements of Article 3.1.3.2. or 9.10.9.12.

### **Section 11.3. Proposed Construction**

#### **11.3.1. New and Existing Building Systems**

##### **11.3.1.1. Material Alteration or Repair of a Building System**

(1) Where an existing *building system* is materially altered or repaired, the *performance level* of the *building* after the material alteration or repair shall be at least equal to the *performance level* of the *building* prior to the material alteration or repair.

##### **11.3.1.2. New Building Systems and Extension of Existing Building Systems**

(1) Except as provided in Article 11.3.3.1. and Section 11.5., the design and *construction* of a new *building system* or the extension of an existing *building system*, shall comply with all other Parts.

#### **11.3.2. Extension of Buildings**

##### **11.3.2.1. Portion of Extended Buildings**

(1) Where an existing *building* is extended,

(a) this Part applies to the existing portion of the *building*, and

(b) the extended portion of the *building* shall comply with all other Parts.

(2) REVOKED: O. Reg. 361/13, s. 97 (2).

### 11.3.3. Renovation

#### 11.3.3.1. Basic Renovation

(1) Except as provided in Sentence (2) and Article 11.3.3.2., *construction* may be carried out to maintain the existing *performance level* of all or part of an existing *building*, by the reuse, relocation or extension of the same or similar materials or components, to retain the existing character, structural uniqueness, heritage value, or aesthetic appearance of all or part of the *building*, if the *construction* will not adversely affect the early warning and evacuation systems, *fire separations* or the structural adequacy or will not create an unhealthy environment in the *building*.

(2) *Construction* in respect of a Group B, Division 3 *occupancy*, a *hotel* or a *retirement home* may be carried out in accordance with Sentence (1) only if the *construction* will be in conformance with the Fire Code made under the *Fire Protection and Prevention Act, 1997*.

#### 11.3.3.2. Extensive Renovation

(1) Where existing interior walls or ceilings or floor assemblies or roof assemblies are substantially removed in an existing *building* and new interior walls, ceilings, floor assemblies or roof assemblies are installed in the *building*, structural and fire-resistance elements shall be constructed in compliance with the requirements of the other Parts.

(2) Except as provided in Section 11.5., the proposed *construction* within an existing *suite* shall comply with the requirements of Section 3.8. where,

(a) new interior walls or floor assemblies are installed,

(b) the *suite* has an area greater than 300 m<sup>2</sup>, and

(c) the *suite* is located in,

(i) a *floor area* where the existing difference in elevation between the adjacent ground level and the floor level is not more than 200 mm, or

(ii) a normally occupied *floor area* which is accessible by a passenger type elevator or other platform equipped passenger elevating device from an entrance *storey* where the existing difference in elevation between the adjacent ground level and the entrance *storey* level is not more than 200 mm.

**(3)** Except as provided in Section 11.5., the proposed *construction* within an existing *suite*, other than a *suite* described in Sentence (2) or a *suite* in a *building* described in Clause 3.8.1.1.(1)(a), (b), (c) or (d), shall comply with the requirements of Sentences 3.8.1.3.(6), 3.8.2.3.(6), 3.8.3.1.(6), 3.8.3.3.(19), 3.8.3.7.(1), 3.8.3.15.(5) and 3.8.3.16.(4) where new interior walls or floor assemblies are installed.

**(4)** Except as provided in Sentence (5), where existing interior walls or ceilings or floor assemblies or roof assemblies are substantially removed on any *storey* in an existing *building* and new interior walls, ceilings, floor assemblies or roof assemblies are installed, the *storey* shall be *sprinklered* if,

(a) the *storey* will contain a Group C *major occupancy*, and

(b) the *building* is over 3 *storeys* in *building height*.

**(5)** Sentence (4) does not apply where the *building*,

(a) conforms to Subclause 3.2.2.44.(1)(a)(ii), and

(b) contains *dwelling units having means of egress conforming to Sentence 3.3.4.4.(8)*.

**(6)** Where existing interior walls or ceilings or floor assemblies or roof assemblies are substantially removed and new interior walls, ceilings, floor assemblies or roof assemblies are installed in an existing *building* or part of an existing *building* that is a *retirement home*, the following requirements apply:

- (a) the *retirement home* shall be *sprinklered*,
- (b) a voice communication system conforming to Article 3.2.4.23. shall be provided in the *building*, if Clause 3.2.6.8.(1)(b) or (c), as applicable, requires that such a voice communication system be provided in the *building*, and
- (c) doors to *suites* and sleeping rooms not within *suites* in the *retirement home*, other than doors leading directly to the exterior, shall be equipped with self-closing devices.

#### **11.3.4. Plumbing**

##### **11.3.4.1. Extension, Material Alteration or Repair**

(1) Despite Subsections 11.3.1. to 11.3.3., when an existing *building* is extended or subject to material alteration or repair, Part 7 applies,

- (a) to the design and *construction of plumbing* in the extensions and those parts of the *building* subject to material alteration and repair, and
- (b) to *plumbing* which is adversely affected by the extension, alteration or repair.

#### **11.3.5. Sewage Systems**

##### **11.3.5.1. Existing Septic Tanks**

(1) Despite Subsections 11.3.1. to 11.3.3., where an existing *septic tank* is subject to material alteration, repair or replacement, the *construction of the septic tank* shall comply with Part 8.

##### **11.3.5.2. Vertical Separations and Existing Sewage Systems**

(1) Despite Subsections 11.3.1. to 11.3.3., where an existing *sewage system* is extended or is subject to material alteration or repair, the requirements respecting the vertical separation to the water table set out in Part 8 apply to the extended, altered or repaired portions of the *sewage system* as well as to the existing portions of the *sewage system*.

### **Section 11.4. Performance Level Evaluation and Compensating Construction**

## 11.4.1. General

### 11.4.1.1. Performance Level

(1) The *performance level* of a *building* after *construction* shall not be less than the *performance level* of the *building* prior to *construction*.

(2) For the purposes of Sentence (1), reduction of *performance level* shall be determined in accordance with Subsection 11.4.2.

(3) Where the proposed *construction* would reduce the *performance level* of an existing *building*, compensating *construction* shall be required in conformance with Subsection 11.4.3.

## 11.4.2. Reduction in Performance Level

### 11.4.2.1. Structural

(1) The *performance level* of an existing *building* is reduced where after proposed *construction* in all or part of an existing *building*,

- (a) the *major occupancy* will change to a different *major occupancy*,
- (b) the *occupant load* will increase by more than 15%, or
- (c) the *live load* will increase due to change in use within the same *major occupancy*,

and the existing structural floor and roof framing systems and their supporting members after the *construction* are not adequate to support the proposed *dead loads* and *live loads*.

### 11.4.2.2. Increase in Occupant Load

(1) Except as provided in Sentences 11.4.2.5.(2) and (3), the *performance level* of an existing *building* is reduced where proposed *construction* will increase the *occupant load* of an existing *building* by more than 15%.



(2) The *performance level* of an existing *building* is reduced where proposed *construction* will increase the *occupant load* by 15% or less and the new *occupant load* will be more than 15% above the *occupant load* for which a fire alarm system is required under Sentence 3.2.4.1.(2).

(3) The *performance level* of an existing *building* is reduced where proposed *construction* will increase the *occupant load* by 15% or less and the new *occupant load* will be more than 15% above the existing *exit* capacity as required under Article 3.4.3.2.

### 11.4.2.3. Change of Major Occupancy

(1) Except as provided in Sentence 11.4.2.5.(4), the *performance level* of an existing *building* is reduced where proposed *construction* will result in,

- (a) the change of the *major occupancy* of all or part of an existing *building* to another *major occupancy* of a greater *hazard index*,
- (b) the conversion of a *suite* of a Group C *major occupancy* into more than one *suite* of Group C *major occupancy*,
- (c) the conversion of a *suite* or part of a *suite* of a Group A, Division 2 or a Group A, Division 4 *major occupancy* into a *gaming premises*,
- (d) the change of a *farm building* or part of a *farm building* to a *major occupancy*,
- (e) the change of a *building* or part of a *building* to a *post-disaster building*,
- (f) the change of a *building* or part of a *building* to a *retirement home*, or
- (g) the change in use of a *building* or part of a *building* where the previous *major occupancy* of the *building* or part of the *building* cannot be determined.

(2) For the purpose of this Article and Sentences 11.4.2.1.(1) and 11.4.2.5.(4), the change of use set out in Clauses (1)(b) to (g) is also deemed to constitute a change in *major occupancy*.

(3) The *performance level* of an existing *building* is reduced where the early warning and evacuation systems requirements of other Parts for the proposed *major occupancy* exceed those of the existing *building*.

(4) The *performance level* of an existing *building* is reduced where the proposed *major occupancy* in the *building* is not separated from the adjoining *major occupancies* by *fire separations* having *fire-resistance ratings* conforming to Tables 3.1.3.1. and 11.4.3.4.B.

(5) The *performance level* of an existing *building* is reduced where the *occupancy* of all or part of an existing *building* of *combustible construction* is changed to a new *major occupancy* that would require the *building*, if it were a new *building*, to be of *noncombustible construction* or to be constructed in accordance with Article 3.2.2.43A. or 3.2.2.50A.

(6) Despite Clause (1)(a), the *performance level* of an existing *building* is reduced where proposed *construction* will result in the change of the *major occupancy* of all or part of an existing *building* to a Group C *major occupancy* in a *building* over 3 *storeys* in *building height*, except in a *building* conforming to Subclause 3.2.2.44.(1)(a)(ii) and having an egress facility conforming to Sentence 3.3.4.4.(8).

#### **11.4.2.4. Plumbing**

(1) The *performance level* of an existing *building* is reduced where the existing *building* is extended or subject to material alteration or repair, and *plumbing* in the existing *building* is adversely affected by the extension, alteration or repair.

#### **11.4.2.5. Sewage Systems**

(1) The *performance level* of an existing *building* is reduced where the existing *building* is extended or subject to material alteration or repair and a *sewage system* serving the existing *building* is adversely affected by the extension, alteration or repair of the existing *building*.

(2) Except as provided in Sentence (3), the *performance level* of an existing *building* is reduced where proposed *construction* will increase the *occupant load* of an existing *building*, and the new *occupant load* will result in the total daily design *sanitary sewage* flow of the *building*, calculated in accordance with Article 8.2.1.3., exceeding the capacity of any component of a *sewage system* serving the *building*.

(3) The *performance level* of an existing *dwelling unit* is reduced where *proposed construction* that,

- (a) increases the number of bedrooms in the *dwelling unit*,
- (b) exceeds 15% of the finished area of the *dwelling unit*, or
- (c) adds new *plumbing fixtures* to the *dwelling unit*,

will result in the total daily design *sanitary sewage* flow of the *dwelling unit*, calculated in accordance with Article 8.2.1.3., exceeding the capacity of any component of a *sewage system* serving the *dwelling unit*.

(4) The *performance level* of an existing *building* is reduced where proposed *construction* will result in the change of a *major occupancy* of all or part of the existing *building* to another *major occupancy* and,

- (a) the total daily design *sanitary sewage* flow of the proposed *major occupancy*, calculated in accordance with Article 8.2.1.3., exceeds the capacity of any component of a *sewage system* serving the *building*, or
- (b) the type or amount of *sanitary sewage* which will, under the proposed *major occupancy*, be discharged to a *sewage system* serving the *building*, is prohibited by Article 8.1.3.1.

#### **11.4.2.6. Extension of Buildings of Combustible Construction**

(1) The *performance level* of an existing *building* of *combustible construction* is reduced where the existing *building* is extended by adding a *storey* or *storeys* such that the extended *building* will be more than four *storeys* in *building height*.

#### **11.4.3. Compensating Construction**

### 11.4.3.1. General

(1) Where the *performance level* of an existing *building* is reduced under Subsection 11.4.2., compensating *construction* shall be carried out in accordance with this Subsection.

(2) Except as provided in Sentence (3), compensating *construction* required under this Subsection applies to the part of the *building* being altered and shall include,

(a) *fire separations*, with the required *fire-resistance ratings*, separating the part being altered from the *floor areas* immediately above and below and from the immediate adjacent areas, and

(b) *access to exits* and *exits* from the *building*, where the alteration adversely affects the *exit* system of the *building*.

(3) Compensating *construction* required under this Subsection applies to the existing *building systems* that are adversely affected by the proposed *construction*.

### 11.4.3.2. Structural

(1) Where the *performance level* of an existing *building* is reduced under Sentence 11.4.2.1.(1),

(a) remedial measures shall be taken to support the proposed loads, or

(b) the portion of the floor affected by the proposed loads shall be restricted to the loading it will support and signs stating the restrictions shall be posted.

### 11.4.3.3. Increase in Occupant Load

(1) Where the *performance level* of an existing *building* is reduced under Sentence 11.4.2.2.(1), (2) or (3), the *building* shall be evaluated, and the early warning and evacuation systems shall be upgraded, in conformance with the applicable requirements of Table 11.4.3.3.

(2) Sentence (1) does not apply in a Group C *occupancy* where the new total *occupant load* is,

- (a) 14 persons or fewer in a *boarding, lodging or rooming house*, except that where the *occupant load* is between 10 and 15 persons, an interconnected system of *smoke alarms* in corridors near stairways is required, or
- (b) 16 persons or fewer in a *building* containing residential *suites* which are *dwelling units*, except that where the *occupant load* is between 10 and 17 persons, an interconnected system of *smoke alarms* in corridors near stairways is required.

**(3)** Where the *performance level* of an existing *building* is reduced under Sentence 11.4.2.2.(1), additional *construction* shall be required in order that the *building* or part of the *building* subject to the increase in *occupant load* conforms to the requirements of Sentence 6.2.2.1.(2), Subsection 3.7.4. and Article 9.31.1.1.

#### **11.4.3.4. Change in Major Occupancy**

**(1)** Where the *performance level* of an existing *building* is reduced under Clause 11.4.2.3.(1)(a), (b), (c), (d), (e) or (g), additional upgrading shall be required in conformance with Table 11.4.3.4.A. and so that the *construction index* of the *building* is increased to at least equal the *hazard index* of the new *major occupancy* that the *building* is to support.

**(2)** A *building* or part of the *building* subject to a change of *major occupancy* shall conform to the requirements of Subsection 3.2.6., Sections 3.7., 3.11., 3.12., Sentences 6.2.2.1.(2), 6.2.3.9.(1) and 6.2.4.7.(10), Subsections 9.5.1. and 9.5.3. to 9.5.10., Section 9.7., Subsection 9.10.17., Sections 9.31. and 9.32., and Subsections 9.34.1. to 9.34.3. as they apply to the new *major occupancy* that the *building* or part of the *building* is to support.

**(3)** Where the *performance level* of an existing *building* is reduced under Sentence 11.4.2.3.(3), the *building* shall be evaluated, and the early warning and evacuation systems shall be upgraded, in conformance with the applicable requirements of Table 11.4.3.3.

**(4)** Where the *performance level* of an existing *building* is reduced under Sentence 11.4.2.3.(4), upgrading of the *fire separations* shall be required in conformance with

the applicable requirements of Article 3.1.3.1. and Table 11.4.3.4.B.

(5) Where the *performance level* is reduced under Sentence 11.4.2.3.(5), the requirement for the *building* to be of *noncombustible construction* or to be constructed in accordance with Article 3.2.2.43A. or 3.2.2.50A. is satisfied if the *building* is *sprinklered*.

(6) Where the *performance level* is reduced under Sentence 11.4.2.3.(6), the *storey* subject to the change shall be *sprinklered*.

(7) Where the *performance level* of an existing *building* is reduced under Clause 11.4.2.3.(1)(f), the following requirements apply:

- (a) the *retirement home* shall be *sprinklered*,
- (b) a voice communication system conforming to Article 3.2.4.23. shall be provided in the *building*, and
- (c) doors to *suites* and sleeping rooms not within *suites* in the *retirement home*, other than doors leading directly to the exterior, shall be equipped with self-closing devices.

#### **11.4.3.5. Plumbing**

(1) Where the *performance level* of an existing *building* is reduced under Sentence 11.4.2.4.(1), upgrading of *plumbing* in the existing *building* which is adversely affected by the extension, alteration or repair shall be required in conformance with Part 7.

#### **11.4.3.6. Sewage Systems**

(1) Where the *performance level* of an existing *building* is reduced under Article 11.4.2.5., upgrading of a *sewage system* which is adversely affected by the *construction*, increase in *occupant load*, increase in the total daily design *sanitary sewage* flow or change in amount or type of *sanitary sewage* shall be required in conformance with Part 8.

#### **11.4.3.7. Extension of Buildings of Combustible Construction**

(1) Where the *performance level* of an existing *building* is reduced under Article 11.4.2.6., the *building* shall be *sprinklered*.

## Section 11.5. Compliance Alternatives

### 11.5.1. Compliance Alternatives

#### 11.5.1.1. Compliance Alternatives

(1) A *compliance alternative* shown in Table 11.5.1.1.A., 11.5.1.1.B., 11.5.1.1.C., 11.5.1.1.D/E. or 11.5.1.1.F. may be substituted for a requirement contained in Part 3, 4, 6 or 8 where the *chief building official* is satisfied that compliance with the requirement is impracticable because,

(a) of structural or *construction* difficulties, or

(b) it is detrimental to the preservation of a *heritage building*.

(2) A *compliance alternative* shown in Table 11.5.1.1.A., 11.5.1.1.B., 11.5.1.1.C., 11.5.1.1.D/E. or 11.5.1.1.F. may be substituted for a requirement contained in Part 9 or 12 without satisfying the *chief building official* that compliance with the requirement is impracticable.

**Table 11.2.1.1.A. Construction Index**  
Forming Part of Sentence 11.2.1.1.(1)

Item	Column 1	Column 2	Column 3	Column 4	Column 5
	<i>Fire-Resistance Rating</i>			Type of <i>Construction</i>	<i>C.I.</i> <sup>(2)</sup>
	Floors over <i>Basement</i>	Other Floors	Roof		
1.	3 h	3 h	1.5 h	<i>Noncombustible</i>	8 <sup>(1)</sup>
2.	2 h	2 h	1 h	<i>Noncombustible</i>	7
3.	1 h	1 h	45 min	<i>Noncombustible</i>	6
4.	45 min	45 min	0 h	<i>Noncombustible</i>	5
5.	45 min	45 min	45 min	<i>Heavy Timber</i>	5
6.	45 min	45 min	45 min	<i>Combustible</i>	5
7.	45 min	0 h	0 h	<i>Noncombustible</i>	4
8.	45 min	45 min	0 h	<i>Combustible</i>	4

9.	30 min	0 h	0 h	<i>Noncombustible</i>	3
10.	30 min	30 min	0 h	<i>Combustible</i>	3
11.	0 h	30 min	0 h	<i>Combustible</i>	2
12.	0 h	0 h	0 h	<i>Combustible</i>	1 <sup>(1)</sup>

**Notes to Table 11.2.1.1.A.:**

- (1) *C.I.* of 1 is lowest fire protection *performance level* and *C.I.* of 8 is highest.
- (2) Take highest rating for *C.I.* from Table 11.2.1.1.A. for existing *building*.

**Table 11.2.1.1.B.** <sup>(1)(4)</sup>**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group A	<i>OccupancyH.I.</i> <sup>(5)</sup>		
	Division 1	Small	Medium	Large
1.	Dinner Theatres	4	5	6
2.	Live Theatres	4	5	6
3.	Motion Picture Theatres	4	5	6
4.	Opera Houses	4	5	6
5.	Television Studios (With Audience)	4	5	6

**Notes to Table 11.2.1.1.B.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)(3)</sup>	
- 300 <i>occupant load</i> maximum / 1 <i>storey</i>	Small
- 600 m <sup>2</sup> / 600 <i>occupant load</i> maximum / 1 <i>storey</i> with less than 40% 2 <i>storey</i> <sup>(6)</sup>	Medium
- Any area / not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I.</i> = 7

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.



(5) Take lowest rating for *H.I.* from Table for *major occupancy* change.

(6) *Building* may have less than 40% of its area as 2 storeys for purposes as described in Clauses 3.2.2.21.(1)(b) and (c).

**Table 11.2.1.1.C. (1)(4)(6)**

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group A	<i>Occupancy H.I.</i> <sup>(5)</sup>		
	Division 2	Small	Medium	Large
1.	Art Galleries	3	4	6
2.	Auditoria	3	4	6
3.	Billiard Halls, Amusement Arcades	3	4	6
4.	Bowling Alleys	3	4	6
5.	Churches	3	4	6
6.	Clubs, Lodges (Non-Residential)	3	4	6
7.	Community Halls	3	4	6
8.	Concert Halls	3	4	6
9.	Court Rooms	3	4	6
10.	Dance Halls	3	4	6
11.	Daycare Centres	3	4	6
12.	Exhibition Halls (Without Sales)	3	4	6
13.	Exhibition Halls (With Sales)	See Group E		
14.	<i>Gaming premises</i>	3	4	6
15.	Gymnasia (Multi-Purpose)	3	4	6
16.	Gymnasia (Athletic)	3	4	6
17.	Lecture Halls	3	4	6
18.	Libraries	3	4	6
19.	Licensed Beverage Establishments	3	4	6
20.	Licensed Clubs, Lodges	3	4	6
21.	Museums	3	4	6
22.	Passenger Stations / Depots	3	4	6
23.	<i>Public Heritage Buildings</i>	3		
24.	Recreational Piers	3	4	6
25.	Restaurants	3	4	6
26.	Schools, Colleges	3	4	6
27.	Undertaking Premises	3	4	6

**Notes to Table 11.2.1.1.C.:**

(1)

<i>Building Size (Maximum) <sup>(2)(3)</sup></i>	
- 400 m <sup>2</sup> / 1 storey	Small
- 250 m <sup>2</sup> / 3 storey ( <i>Public Heritage Building</i> )	Small
- 800 m <sup>2</sup> / 2 storey	Medium
- Any area / not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I. = 7</i>

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) Take lowest rating for *H.I.* from Table for *major occupancy* change.

(6) *Buildings* which exceed 3 *storeys* in *building height* and are of *combustible construction* shall be *sprinklered*.

**Table 11.2.1.1.D. <sup>(1)(4)</sup>****Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group A	<i>Occupancy H.I. <sup>(5)</sup></i>		
	Division 3	Small	Medium	Large
1.	Arenas (No Occupancy On Activity Surface)	3	4	6
2.	Armouries (No Occupancy On Activity Surface)	3	4	6
3.	Enclosed Stadia or Grandstand	3	4	6
4.	Ice Rinks (No Occupancy On Activity Surface)	3	4	6
5.	Indoor Swimming Pools	3	4	6

**Notes to Table 11.2.1.1.D.:**

(1)

<i>Building Size (Maximum) <sup>(2)(3)</sup></i>

- 1000 m <sup>2</sup> / 1 storey	Small
- 2000 m <sup>2</sup> / 2 storey	Medium
- Any area / not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I.</i> = 7

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) Take lowest rating for *H.I.* from Table for *major occupancy* change.

**Table 11.2.1.1.E.** <sup>(1)(3)</sup>

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group A	<i>Occupancy H.I.</i> <sup>(4)</sup>		
	Division 4	Small	Medium	Large
1.	Amusement Park Structures	2	3	5
2.	Bleachers	1	3	5
3.	Grandstands (Open)	1	3	5
4.	Reviewing Stands	1	3	5
5.	Stadia (Open)	1	3	5

**Notes to Table 11.2.1.1.E.:**

(1)

<i>Building Size</i> (Maximum) <sup>(2)</sup>	
- 2,500 <i>occupant load</i> max. / min. <i>limiting distance</i> of 6 m ( <i>combustible</i> )	Small
- 15,000 <i>occupant load</i> maximum (with roof at least ½ rating if <i>combustible</i> )	Medium
- Unlimited <i>occupant load</i>	Large

(2) *Building* size is based on the existing *building* facing one *street*.

(3) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(4) Take lowest rating for *H.I.* from Table for *major occupancy* change.

(5) REVOKED: O. Reg. 191/14, s. 137 (3).

**Table 11.2.1.1.F. (1)**

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group B	<i>Occupancy H.I.</i> <sup>(3)(5)</sup>		
	Division 1	Small	Medium	Large
1.	Detention Facilities (Minimum Security) <sup>(4)</sup>	4	5	6
2.	Detention Facilities (All Other Types of Security)	6	6	7
3.	Police Station with Detention	3		

**Notes to Table 11.2.1.1.F.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)</sup>	
- Any area / 1 storey	Small
- 600 m <sup>2</sup> / 1 storey (Police Station with Detention)	Small
- Any area ( <i>noncombustible</i> ) / 2 storey	Medium
- Any area ( <i>noncombustible</i> ); 500 m <sup>2</sup> ( <i>combustible</i> ) / 2 storey	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top storey ( <i>noncombustible</i> )	<i>H.I.</i> = 7
- Over 500 m <sup>2</sup> ( <i>combustible</i> ) / over 2 storey	<i>H.I.</i> = 7

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

(4) Minimum security means occupants free to exit *building* in a fire emergency.

(5) *Detention occupancy* with any *H.I.* shall be *sprinklered*.

**Table 11.2.1.1.G. (1)(4)**

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4

	Group B	Occupancy H.I. <sup>(5)(7)</sup>		
		Small	Medium	Large
1.	Hospital, Long-Term Care Home(Immobile) <sup>(6)</sup>	4	5	7
2.	Hospital, Long-Term Care Home (Non-Ambulatory) <sup>(6)</sup>	4	5	6
3.	Hospital, Long-Term Care Home (Ambulatory) <sup>(6)</sup>	3	4	6
4.	Psychiatric Facility (Maximum Confinement)	4	5	7
5.	Psychiatric Facility (Minimum Confinement)	3	4	6
6.	Police Station With Detention (as Permitted in Article 3.1.2.4.)	3		

**Notes to Table 11.2.1.1.G.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)(3)</sup>	
- 250 m <sup>2</sup> / 1 storey	Small
- 600 m <sup>2</sup> / 1 storey (Police Station with Detention)	Small
- 500 m <sup>2</sup> / 2 storey; 1000 m <sup>2</sup> / 1 storey	Medium
- Any area ( <i>noncombustible</i> ); 500 m <sup>2</sup> ( <i>combustible</i> ) / 2 storey	Medium
- Any area / not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top storey	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top storey	<i>H.I. = 7</i>

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

(6) Immobile means patients are attached to life support systems and cannot be moved. Non-Ambulatory means patients are confined to bed and require transportation. Ambulatory means patients may walk on their own.

(7) *Care and treatment occupancy* with any *H.I.* shall be *sprinklered*.

**Table 11.2.1.1.H. (1)****Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group B	<i>Occupancy H.I.</i> <sup>(4)(5)</sup>		
	Division 3	Small	Medium	Large
1.	Residential care facilities			
	(Ambulatory) <sup>(6)</sup>	3	4	6
	(Non-Ambulatory) <sup>(6)</sup>	4	5	6
2.	Children Custodial Homes	3	4	6
3.	Convalescent Homes			
	(Ambulatory) <sup>(6)</sup>	3	4	6
	(Non-Ambulatory) <sup>(6)</sup>	4	5	6
4.	Group Homes For Adult Residents with Developmental Disabilities			
	(Minimum Confinement)	3	4	6
	(Maximum Confinement)	4	5	6

**Notes to Table 11.2.1.1.H.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)(3)</sup>	
- 600 m <sup>2</sup> / 1 storey	Small
- 500 m <sup>2</sup> / 2 storey; 1000 m <sup>2</sup> / 1 storey	Medium
- Any area / not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top storey	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top storey	<i>H.I. = 7</i>

(2) Sizes are based on *building area* and *building height*, unless noted.(3) *Building* size is based on the existing *building* facing one *street*.(4) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.(5) *Care occupancy* with any *H.I.* shall be *sprinklered*.

(6) Non-Ambulatory means patients are confined to bed and require transportation. Ambulatory means patients may walk on their own.

**Table 11.2.1.1.I. (1)****Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group C	<i>Occupancy H.I.</i> <sup>(4)</sup>		
		Small	Medium	Large
1.	Apartments	3	4	6
2.	Boarding Houses/Group Homes	3		
3.	Clubs, Residential	3	4	6
4.	Colleges, Residential	3	4	6
5.	Convents	3	4	6
6.	Dormitories/Hostels	3	4	6
7.	<i>Hotels</i>	3	5	6
8.	<i>Houses</i>	2	2	
9.	Lodging Houses	3		
10.	<i>Live/work units</i>	4	5	7
11.	Monasteries	3	4	6
12.	<i>Public Heritage Buildings</i>	3		
13.	Rectories	2		
14.	<i>Retirement Homes</i>	3	4	6
15.	Rooming Houses	3		
16.	Schools, Residential	3	4	6

**Notes to Table 11.2.1.1.I.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)(3)</sup>	
- 600 m <sup>2</sup> / 3 storey	Small
- 250 m <sup>2</sup> / 3 storey ( <i>Public Heritage Building</i> )	Small
- 2000 m <sup>2</sup> / not exceeding 6 storeys	Medium
- Any area / not exceeding 36 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	Large
- Over 36 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I. = 7</i>
- <i>Hotels</i> over 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I. = 7</i>

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Buildings which exceed 3 storeys in building height and are of combustible construction shall be sprinklered.*

(4) Take lowest rating for *H.I.* from Table for *major occupancy* change.

**Table 11.2.1.1.J. (1)(4)(6)**

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group D	<i>Occupancy H.I.</i> <sup>(5)</sup>		
		Small	Medium	Large
1.	Advertising and Sales Offices	3	3	5
2.	Automatic Bank Deposit	3	4	5
3.	Barber/Hairdresser Shops	3	4	5
4.	Beauty Parlours	3	4	5
5.	Branch Banks	3	4	5
6.	Car Rental Premises	3	3	5
7.	Chiropractic Offices	3	4	5
8.	Communications Offices (Telecommunications)	3	4	5
9.	Communications Offices (Courier)	3	3	5
10.	Computer Centres	3	4	5
11.	Construction Offices	3	3	5
12.	Costume Rental Premises	3	4	5
13.	Dental Offices (Denture Clinic)	3	4	5
14.	Dental Offices (General)	3	4	5
15.	Dental Offices (Surgical/Anaesthesia)	4	5	6
16.	Dry Cleaning Depots	3	4	5
17.	Dry Cleaning Premises (Self-Serve)	4	4	5
18.	Health/Fitness Clubs	3	4	5
19.	Laundries (Self-Serve)	4	4	5
20.	Massage Parlours	3	4	5
21.	Medical Offices (Examination)	3	4	5
22.	Medical Offices (Surgical/Anaesthesia)	4	5	6
23.	Offices (Business)	3	3	5
24.	Offices (Charitable)	3	3	5
25.	Offices (Legal/Accounting)	3	3	5



26.	Offices/Studios (Design)	3	4	5
27.	Pharmacy Offices	3	4	5
28.	Photographic Studios	3	4	5
29.	Physiotherapy Offices	3	4	5
30.	Police Stations (No Detention)	3	4	5
31.	Printing and Duplicating	4	5	6
32.	<i>Public Heritage Buildings</i>	3		
33.	Public Saunas	3	4	5
34.	Radio Stations (No Audience)	3	4	5
35.	Small Tool Rental Premises	3	4	5
36.	Suntan Parlours	3	4	5
37.	Veterinary Offices	3	4	5

**Notes to Table 11.2.1.1.J.:**

(1)

<i>Building Size (Maximum) (2)(3)</i>	
- 800 m <sup>2</sup> / 2 storey	Small
- 250 m <sup>2</sup> / 3 storey ( <i>Public Heritage Building</i> )	Small
- 1600 m <sup>2</sup> / 3 storey	Medium
- Any area / not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i> , but not exceeding 36 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I.</i> = 6
- Over 36 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I.</i> = 7

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

(6) *Buildings* which exceed 3 storeys in *building height* and are of *combustible construction* shall be *sprinklered*.

**Table 11.2.1.1.K. (1)(4)(6)****Hazard Index**

## Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group E	<i>Occupancy H.I.</i> <sup>(5)</sup>		
		Small	Medium	Large
1.	Automotive/Hardware Department Stores	4	5	7
2.	China Shops	3	4	6
3.	Department Stores	4	5	7
4.	Electrical Stores (Fixtures)	3	3	5
5.	Exhibition Halls (With Sales)	4	5	7
6.	“Fast Food” Outlets	3	4	5
7.	Feed and Seed Stores	4	5	7
8.	Flea Markets	4	5	7
9.	Flowers Shops	3	4	6
10.	“Food” and Vegetable Markets	3	4	6
11.	Garden Shops	3	4	6
12.	“Gas” Bars	4	5	7
13.	Gift Shops	3	4	6
14.	Home Improvement Stores	4	5	7
15.	Kitchen/Bathroom Cupboards Stores	3	4	6
16.	Plumbing Stores (Fixtures/Accessories)	3	3	5
17.	“Pop” Shops	3	4	6
18.	<i>Public Heritage Buildings</i>	3		
19.	Rentals (See “Group D”)			
20.	Restaurants (Not More Than 30 Persons as Permitted by Article 3.1.2.6.)	3	4	5
21.	Shopping Malls	4	5	7
22.	Stationery/Office Supply Stores	3	4	6
23.	Stores (Art)	3	4	6
24.	Stores (Baked Goods)	3	4	6
25.	Stores (Beer)	3	4	6
26.	Stores (Book)	3	4	6
27.	Stores (Camera)	3	4	6
28.	Stores (Candy)	3	4	6
29.	Stores (Clothing)	3	4	6
30.	Stores (Drugs)	4	4	6
31.	Stores (Electronic)	3	4	6
32.	Stores (Floor Coverings)	4	5	7

33.	Stores (Food)	3	3	6
34.	Stores (Furniture/Appliances)	3	4	6
35.	Stores (Hardware)	4	5	7
36.	Stores (Health)	4	4	6
37.	Stores (Hobby)	3	4	6
38.	Stores (Jewellery)	3	3	5
39.	Stores (Paint/Wallpaper)	4	5	7
40.	Stores (Pet)	3	4	6
41.	Stores (Records/Tapes)	3	4	6
42.	Stores (Spirits)	4	5	7
43.	Stores (Toys)	4	5	7
44.	Stores (Variety)	4	4	6
45.	Stores (Video Sales/Rental)	3	4	6
46.	Supermarkets	3	4	6

**Notes to Table 11.2.1.1.K.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)(3)</sup>	
- 600 m <sup>2</sup> / 2 storey	Small
- 250 m <sup>2</sup> / 3 storey ( <i>Public Heritage Building</i> )	Small
- 800 m <sup>2</sup> / 3 storey	Medium
- Any area / up to 18 m high, measured between <i>grade</i> and the floor level of the top storey	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top storey	<i>H.I. = 7</i>

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

(6) All *buildings* 1 500 m<sup>2</sup> and over are to be *sprinklered*.

**Table 11.2.1.1.L.** <sup>(1)(4)(5)</sup>**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column	Column	Column
------	----------	--------	--------	--------

		2	3	4
Group F		<i>Occupancy H.I.</i> <sup>(3)</sup>		
Division 1		Small	Medium	Large
1.	Ammunition Manufacturing and Storage	3	6	8
2.	Black Powder Manufacturing and Storage	3	6	8
3.	Bulk Plants for Flammable Liquids	3	6	8
4.	Bulk Storage Warehouse (Hazardous Substances)	3	6	8
5.	Cereal and Feed Mills	3	6	8
6.	Chemical Manufacturing/Processing Plant	3	6	8
7.	<i>Distilleries</i>	3	6	8
8.	Dry Cleaning Plants (Flammable)	3	6	8
9.	Explosives Manufacturing and Storage	3	6	8
10.	Fertilizer Manufacturing Plants	3	6	8
11.	Fireworks Manufacturing and Storage	3	6	8
12.	Flour Mills	3	6	8
13.	Gas (Flammable) Compressor Stations	3	6	8
14.	Gas (Flammable) Manufacturing and Storage	3	6	8
15.	Grain Elevators	3	6	8
16.	Lacquer Factories	3	6	8
17.	Loading Area for all Group F, Division 1	3	6	8
18.	Mattress Factories (High Fire Load)	3	6	8
19.	Paint/Varnish/Pyroxylin Factories	3	6	8
20.	Petrochemical Plants	3	6	8
21.	Refineries	3	6	8
22.	Rubber Processing Plants	3	6	8
23.	Spray Painting Operations	3	6	8
24.	Waste Paper Processing Plants (Dry)	3	6	8

**Notes to Table 11.2.1.1.L.:**

(1)

*Building Size (Maximum)*<sup>(2)</sup>

- 400 m<sup>2</sup> / 2 storey

Small

- 600 m <sup>2</sup> / 4 storey	Medium
- 1 500 m <sup>2</sup> / 4 storey	Large

(2) Sizes are based on *building area* and *building height*.

(3) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

(4) All *buildings* 1 500 m<sup>2</sup> and over are to be *sprinklered*.

(5) All floor assemblies shall be *fire separations*.

**Table 11.2.1.1.M. (1)(4)(6)**

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group F	<i>Occupancy H.I.</i> <sup>(5)</sup>		
	Division 2	Small	Medium	Large
1.	Aircraft Hangars	3	5	6
2.	Abattoirs	3	4	5
3.	Bakeries	3	5	6
4.	Body Shops	3	5	6
5.	Candy Plants	3	4	5
6.	<i>Cold Storage Plants</i>	3	5	7
	<i>Combustible</i> Insulation			
	Flammable Refrigerant			
	<i>Combustible</i> Packaging			
	<i>Combustible</i> Insulation	3	5	6
	Flammable Refrigerant			
	<i>Noncombustible</i> Packaging			
	<i>Combustible</i> Insulation	3	4	5
	Non-Flammable Refrigerant			
	<i>Noncombustible</i> Packaging			
	<i>Noncombustible</i> Insulation	2	3	4
	Non-Flammable Refrigerant			
	<i>Noncombustible</i> Packaging			
7.	Dry Cleaning Establishments (Non-flammable or Non-explosive)	3	4	5
8.	Electrical Substations	3	4	5
9.	Factories (High Fire Load)	3	5	6
10.	Freight Depots (High Fire Load)	3	5	6
11.	Helicopter Landings (On Roof)	3	4	5

12.	Laboratories (High Fire Load)	3	5	6
13.	Laundries (Not Self-Serve)	3	4	5
14.	Manufacturer Sales (High Fire Load)	3	5	6
15.	Mattress Factories	3	4	5
16.	Meat Packing Plants	3	4	5
17.	Packaging Manufacturers (Cellulose)	3	4	5
18.	Packaging Manufacturers (Noncombustible)	2	3	4
19.	Packaging Manufacturers (Plastics)	3	5	6
20.	Paper Processing Plants (Wet)	3	5	6
21.	Planing Mills	3	5	6
22.	Printing Plants	3	4	5
23.	<i>Public Heritage Buildings</i>	3	3	
24.	Repair Garages	3	5	6
25.	Sample Display Rooms (High Fire Load)	3	5	6
26.	Self-Service Storage Buildings	3	4	5
27.	Service Stations (No Spray Painting)	3	5	6
28.	Storage Rooms (High Fire Load)	3	5	6
29.	Television Studios (No Audience)	3	4	5
30.	Tire Storage	3	5	6
31.	Warehouses (High Fire Load)	3	5	6
32.	Welding Shops	3	5	6
33.	Wholesale Rooms (High Fire Load)	3	5	6
34.	Wood Working Factories	3	5	6
35.	Workshops (High Fire Load)	3	5	6

**Notes to Table 11.2.1.1.M.:**

(1)

<i>Building Size (Maximum) <sup>(2)(3)</sup></i>	
- 600 m <sup>2</sup> / 2 storey	Small
- 800 m <sup>2</sup> / 4 storey	Medium
- 600 m <sup>2</sup> / 3 storey ( <i>Public Heritage Building</i> )	Medium
- Any area / 6 storey not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	Large
- Over 18 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I. = 7</i>

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

(6) All *buildings* 1 500 m<sup>2</sup> and over are to be *sprinklered*.

**Table 11.2.1.1.N. (1)(4)**

**Hazard Index**

Forming Part of Sentences 11.2.1.1.(1) and (2)

Item	Column 1	Column 2	Column 3	Column 4
	Group F	<i>Occupancy H.I.</i> <sup>(5)</sup>		
	Division 3	Small	Medium	Large
1.	Creameries	2	2	3
2.	Factories (Low Fire Load)	2	3	4
3.	Freight Depots (Low Fire Load)	2	3	4
4.	Laboratories (Low Fire Load)	2	3	4
5.	Manufacturers Sales (Low Fire Load)	2	3	4
6.	Power Plants	3	4	5
7.	<i>Public Heritage Buildings</i>	3	3	
8.	Sample Display Rooms (Low Fire Load)	2	3	4
9.	Storage Garages	2	3	4
10.	Storage Rooms (Low Fire Load)	2	3	4
11.	Warehouses (Low Fire Load)	2	3	4
12.	Wholesale Rooms (Low Fire Load)	2	3	4
13.	Workshops (Low Fire Load)	2	3	4

**Notes to Table 11.2.1.1.N.:**

(1)

<i>Building Size (Maximum)</i> <sup>(2)(3)</sup>	
- 800 m <sup>2</sup> / 2 storey	Small
- 1200 m <sup>2</sup> / 4 storey	Medium
- 600 m <sup>2</sup> / 3 storey ( <i>Public Heritage Building</i> )	Medium
- Any area / 6 storey not exceeding 18 m high, measured between <i>grade</i> and the floor level of the top storey	Large
- Over 18 m, but not exceeding 36 m high, measured	<i>H.I.</i> = 5

between <i>grade</i> and the floor level of the top <i>storey</i>	
- Over 36 m high, measured between <i>grade</i> and the floor level of the top <i>storey</i>	<i>H.I.</i> = 6

(2) Sizes are based on *building area* and *building height*, unless noted.

(3) *Building* size is based on the existing *building* facing one *street*.

(4) For existing *buildings* facing multiple *streets*, see Sentence 11.2.1.1.(2) and Table 11.4.3.4.A.

(5) When the size of a *building* falls into more than one category, the *H.I.* for the least restrictive is permitted to be used.

**Table 11.4.3.3.**  
**For Evaluation and Upgrading of Early Warning/Evacuation**

Forming Part of Sentences 11.4.3.3.(1) and 11.4.3.4.(3)

Col. 1	Column 2	Column 3
Notes	Early Warning and Evacuation,	Part 11
	Evaluation and Upgrading	<i>Compliance Alternative</i> <sup>(1)</sup>
	Early warning and evacuation to be checked against	
	(a) <i>access to exit</i> widths based on <i>occupant load</i> in Subsection 3.3.1. or 9.9.3.;	EARLY WARNING
	(b) <i>exit</i> widths based on <i>occupant load</i> in Subsection 3.4.3. or 9.9.3.;	(a) <i>Compliance alternatives</i> as listed may be used.
	(c) <i>exit</i> signs in Subsection 3.4.5. or 9.9.11.;	
(2)	(d) lighting of <i>exits</i> , lighting of <i>access to exits</i> and emergency lighting in Subsection 3.2.7. or 9.9.12.;	EVACUATION
	(e) fire alarm system in Subsection 3.2.4. or 9.10.18.;	(b) <i>Compliance alternatives</i> as listed to <i>access to exit</i> and <i>exit</i> widths, number of <i>exits</i> , door release hardware, and travel distance may be used.
	(f) <i>smoke alarms</i> in Subsection 9.10.19.;	
	(g) travel distance and number of <i>exits</i> in other Parts; and	
	(h) door release hardware requirements in Articles 3.3.1.12. and 3.4.6.16.,	
	and deficiencies shall be upgraded.	
	Early warning and evacuation to be	



	checked against	
	(a) <i>access to exit</i> widths based on <i>occupant load</i> in Subsection 3.3.1. or 9.9.3.;	
	(b) <i>exit</i> widths based on <i>occupant load</i> in Subsection 3.4.3. or 9.9.3.;	
	(c) <i>exit</i> signs in Subsection 3.4.5. or 9.9.11.;	EARLY WARNING
	(d) lighting of <i>exits</i> , lighting of <i>access to exits</i> and emergency lighting in Subsection 3.2.7. or 9.9.12.;	(a) <i>Compliance alternatives</i> as listed may be used.
(3)	(e) fire alarm system in Subsection 3.2.4. or 9.10.18.;	
	(f) <i>smoke alarms</i> in Subsection 9.10.19.;	EVACUATION
	(g) travel distance and number of <i>exits</i> in other Parts;	(b) <i>Compliance alternatives</i> as listed to <i>access to exit</i> and <i>exit</i> widths, number of <i>exits</i> , door release hardware, and travel distance may be used.
	(h) smoke control measures, and at least one elevator to permit transport of firefighters to all floors in <i>hotels</i> whose floor level is more than 18 m high measured between <i>grade</i> and floor level of the top <i>storey</i> as per Subsection 3.2.6., and	
	(i) door release hardware requirements in Articles 3.3.1.12. and 3.4.6.16.,	
	and deficiencies shall be upgraded.	

**Notes to Table 11.4.3.3.:**

- (1) See Tables 11.5.1.1.A. to 11.5.1.1.F. for *compliance alternatives* that may be used.
- (2) Applies to change of *major occupancy* to one of equal or lesser hazard, and to increase in *occupant load* by 15% or less.
- (3) Applies to change of *major occupancy* to one of greater hazard, and to increase in *occupant load* greater than 15%.

**Table 11.4.3.4.A.  
Additional Upgrading**

Forming Part of Sentences 11.2.1.1.(2) and 11.4.3.4.(1)

Item	Column 1	Column 2	Column 3	Column 4	Column 5
	New <i>Major Occupancy</i>	Increase of <i>C.I.</i> to Equal	Additional Required	Part 11	Comments <sup>(1),(2)</sup>

	(H.I.) Number <sup>(3)</sup>	H.I. to Support New	Upgrading	Alternative	
		<i>Major Occupancy</i>		Compliance (A.C.)	
1.	H.I.2	C.I. 1 to 2	Comply with Table 11.2.1.1.A. ratings for C.I. of 2	(a) Provide early warning system, or	
				(b) Comply with any A.C.'s in Col. 4.	
2.	H.I.3	C.I. (1 or 2) to 3	Comply with Table 11.2.1.1.A. ratings for C.I. of 3	(a) Provide early warning system, or	<i>Combustible to Combustible only.</i>
				(b) Comply with any A.C.'s in Col. 4.	
3.	H.I.4	C.I. (1, 2 or 3) to 4	Comply with Table 11.2.1.1.A. ratings for C.I. of 4	Provide sprinklers in locations where assemblies do not comply with Table 11.2.1.1.A.	<i>Combustible to Combustible. Noncombustible to Noncombustible.</i>
4.	H.I.5	C.I. 4 to 5	Comply with Table 11.2.1.1.A. ratings for C.I. of 5	Provide sprinklers in locations where assemblies do not comply with Table 11.2.1.1.A.	
5.	H.I.5	C.I. (1, 2 or 3) to 5	Comply with Table 11.2.1.1.A. ratings	Provide sprinklers in locations where	<i>Combustible to Combustible. Noncombustible to Noncombustible.</i>

			for C.I. of 5	assemblies do not comply with Table 11.2.1.1.A.	
6.	H.I.6	C.I. 5 (Noncombustible) to 6	Comply with Table 11.2.1.1.A. ratings for C.I. of 6	(a) Provide sprinkler system, plus 45 min roof rating.	
7.	H.I.6	C.I. 5 (Heavy timber) to 6	Comply with A.C.	(b) Provide sprinkler system.	
8.	H.I.6	C.I. 5 (Combustible) to 6	Comply with A.C.	(c) Provide 1 h rating plus sprinkler system.	
9.	H.I.6	C.I. (3 or 4) to 6*	Comply with Table 11.2.1.1.A. ratings for C.I. of 6	(d) Provide sprinkler system, plus 45 min rating.	* For Noncombustible construction only.
10.	H.I.6	C.I. (1, 2, 3 or 4) to 6**	Comply with A.C.	(e) Provide 1 h rating plus sprinkler system.	** For Combustible construction only.
11.	H.I.7	C.I. 6 to 7	Comply with Table 11.2.1.1.A. ratings for C.I. of 7	(a) Provide sprinkler system.	
12.	H.I.7	C.I. (3, 4 or 5) to 7*	Comply with Table 11.2.1.1.A. ratings for C.I. of 7	(b) Provide 1 h rating plus sprinkler system.	* For Noncombustible construction only.
13.	H.I.8	C.I. 7 to 8	Comply with Table 11.2.1.1.A. ratings	(a) Provide sprinkler system.	

			for C.I. of 8		
14.	H.I.8	C.I. 6 to 8	Comply with Table 11.2.1.1.A. ratings for C.I. of 8	(b) Provide supervised sprinkler system.	
15.	H.I.8	C.I. (3, 4 or 5) to 8*	Comply with Table 11.2.1.1.A. ratings for C.I. of 8	(d) Provide sprinkler system, plus 1 h rating.	* For Noncombustible construction only.

**Notes to Table 11.4.3.4.A.:**

- (1) One asterisk (\*) refers to *noncombustible construction*.
- (2) Two asterisks (\*\*) refers to *combustible construction*.
- (3) Group B, *occupancy* with any H.I. shall be *sprinklered*.

**Table 11.4.3.4.B.<sup>(1)</sup>**

**Additional Upgrading for Multiple Major Occupancies**

Forming Part of Sentences 11.4.2.3.(4) and 11.4.3.4.(4)

Column 1	Column 2	Column 3	Column 4
New Major Occupancy	Code Requirements	Part 11 Compliance Alternative	
All <sup>(2)</sup>	Table 3.1.3.1. and Subsection 9.10.9.	For Existing Building	If Sprinklered
	Where:	Reduce to	Reduce to
	1 h rating required	45 min	30 min
	2 h rating required	1.5 h	1 h
	3 h rating required	2 h	1.5 h

**Notes to Table 11.4.3.4.B.:**

- (1) For *buildings* with multiple *major occupancies* only, where there is a change in *major occupancy*.
- (2) See Section 11.4.

**Table 11.5.1.1.A.**  
**Compliance Alternatives for Assembly Occupancies**

Forming Part of Article 11.5.1.1.

Item	Col. 1 NUMBER	Column 2 <b>PART 3 REQUIREMENTS</b>	Column 3 <b>PART 11 COMPLIANCE ALTERNATIVE</b>
1.	A1	3.1.4.7.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of member sizes listed in Part 3.
2.	A2	3.1.5.2. to 3.1.5.4.; 3.1.5.6.	Existing acceptable.
3.	A3	3.1.5.7. to 3.1.5.10.	Except for exposed foamed plastics, existing acceptable. To match existing, materials may be added from on or off site.
4.	A4	3.1.5.15. to 3.1.5.17.; 3.1.5.21.; 3.1.5.23.	Existing acceptable.
5.	A5	3.1.7.1.	<i>Fire-resistance ratings</i> may also be used where they are based on:
			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".
			3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".
			4. DBR Technical Paper No. 222, "Fire Endurance of Light-Framed and Miscellaneous Assemblies".
6.	A6	3.1.7.5.(3)	Existing assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
7.	A7	3.1.8.5.(2)	(a) Existing functional and sound doors in existing <i>buildings</i> that are either hollow metal or kalamein and containing wired glass at least 6 mm thick and conforming to

			Sentence 3.1.8.14.(2) are permitted in lieu of doors not required to exceed 45 min,
			(b) all existing functional and sound hollow metal or kalamein doors which carry existing 1.5 h labels are acceptable in lieu of current 1.5 h labels and may contain wired glass panels not exceeding 0.0645 m <sup>2</sup> , at least 6 mm thick and conforming to Sentence 3.1.8.14.(2), and
			(c) every fire door, window assembly or glass block used as a <i>closure</i> in a required <i>fire separation</i> shall be installed in conformance with good engineering practice.
8.	A8	3.1.8.7. to 3.1.8.9.	<i>Fire dampers</i> or <i>fire stop flaps</i> are not required to be installed in existing ducts at penetrations of existing <i>fire separations</i> .
9.	A9	3.1.8.10.(1)	Existing 45 mm solid core wood doors acceptable.
10.	A10	3.1.8.11.(1)	Existing functionally operable self-closing devices acceptable.
11.	A11	3.1.8.13.	Existing functionally operable latching devices, excluding draw bolts, are acceptable.
12.	A12	3.1.8.14.	Existing transoms or sidelights located in required <i>fire separations</i> may be retained if wired glass at least 6 mm thick is securely fixed to a steel frame with steel stops. Operable transoms shall be fixed closed.
13.	A13	3.1.8.15. to 3.1.8.17.	Existing acceptable.
14.	A14	3.1.11.	Where the concealed space is being materially altered, smoke or heat detection in that space in lieu of <i>fire blocks</i> and tied into fire alarm system is acceptable.
15.	A15	3.1.13.10.	Existing acceptable.
16.	A16	3.2.2.17.(1)(b) and (c)	Existing sprinkler systems need not comply.

17.	A17	3.2.3.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies not closer than 300 mm from a window in such other <i>building</i> , where the “opposite” window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, shall be restricted to the same <i>fire compartment</i> and shall conform to the requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
18.	A18	3.2.3.6.(3)	Existing roof soffit projections acceptable.
19.	A19	3.2.4.	(a) Existing fire alarm system may remain except that Article 3.2.4.5. does not apply where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as required,

			Fire Department connection and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
20.	A20	3.2.4.9.(2)(e)	Does not apply to existing installations in <i>buildings</i> .
21.	A21	3.2.4.10.(5)(c)	Does not apply to existing installations in <i>buildings</i> .
22.	A22	3.2.5.3.(1) and (2)	Existing acceptable.
23.	A23	3.2.5.4. to 3.2.5.6.	Existing acceptable provided the <i>building</i> is <i>sprinklered</i> .
24.	A24	3.2.5.7.	Does not apply, except where a change in <i>major occupancy</i> occurs from a lesser <i>hazard index</i> .
25.	A25	3.2.5.13.	Existing sprinkler systems in existing <i>buildings</i> that do not conform to NFPA 13 may be altered, added to, or extended from the existing system without complying with NFPA 13, provided the system is operational and adequate with respect to coverage, water supply and controls, and provided the system is evaluated by a qualified designer.
26.	A26	3.2.9.	(a) Does not apply to <i>buildings</i> 6 storeys and less.
			(b) Does not apply to <i>sprinklered buildings</i> .
27.	A27	3.3.1.5.	One egress door is allowed where the <i>occupant load</i> is not greater than 100 persons, provided <i>floor area</i> is <i>sprinklered</i> and travel distance does not exceed 25 m.
28.	A28	3.3.1.9.	Existing width of <i>public corridors</i> of not less than 914 mm is acceptable.
29.	A29	3.3.1.9.(8)	An existing dead end corridor is permitted where the <i>occupant load</i> is not greater than 20 persons, provided travel distance is not greater than 6 m plus corridor width to “ <i>exit choice</i> ” point.
30.	A30	3.3.1.10.; 3.3.1.11.	Existing door swings may remain



			in <i>heritage buildings</i> , existing or being restored, with no change in <i>major occupancy</i> and with <i>occupant load</i> no greater than 100.
31.	A31	3.3.1.12.	Existing doors may remain in a <i>heritage building</i> , existing or being restored, with no change in <i>major occupancy</i> .
32.	A32	3.3.1.18.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
33.	A33	3.3.5.4.(1); 3.3.5.7.(1) to (3)	Need not comply where a gasketed door and self closer are provided in the existing <i>fire separation</i> .
34.	A34	3.4.1.5.(1)	Existing acceptable.
35.	A35	3.4.1.5.(2)	Existing acceptable provided the existing <i>guard</i> is not less than 914 mm.
36.	A36	3.4.1.8.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
37.	A37	3.4.2.5.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> and where there is no change in <i>major occupancy</i> .
38.	A38	3.4.3.2.(5)	Need not comply where there is no increase in <i>occupant load</i> .
39.	A39	3.4.3.2.(7)	Existing width of <i>exits</i> acceptable provided the <i>occupant load</i> is not more than 15% above the <i>exit</i> capacity.
40.	A40	3.4.3.4.	Existing acceptable.
41.	A41	3.4.3.5.	Existing headroom clearance of not less than 1 980 mm is acceptable.
42.	A42	3.4.4.4.(8)	Existing washrooms opening directly into an <i>exit</i> stairwell shall be separated from the <i>exit</i> stairwell by a 45 min <i>closure</i> .
43.	A43	3.4.5.1.(2) and (9)	Existing illuminated legible <i>exit</i> signs are acceptable.
44.	A44	3.4.6.2.	Existing acceptable, if visually apparent.
45.	A45	3.4.6.3.	Existing acceptable.
46.	A46	3.4.6.4.	Existing acceptable.

47.	A47	3.4.6.5.(2) to (11)	Existing acceptable.
48.	A48	3.4.6.6.(2), (4) and (5)	Existing acceptable.
49.	A49	3.4.6.7.(1)	Existing acceptable.
50.	A50	3.4.6.8.	Existing acceptable.
51.	A51	3.4.6.9.	Existing acceptable.
52.	A52	3.4.6.11.(1), (2) and (4)	Existing acceptable.
53.	A53	3.4.6.12.	Existing acceptable in <i>public heritage buildings</i> or a change in <i>occupancy</i> with no increase in <i>occupant load</i> .
54.	A54	3.4.6.16.(2) and (3)	Existing functionally operable panic hardware acceptable.
55.	A55	3.4.7.2.	<i>Combustible</i> fire escapes which are protected from fire in accordance with Sentence 3.2.3.14.(2) are permitted or may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
56.	A56	3.5.1.	Existing acceptable.
57.	A57	3.6.2.1.(7)	Existing <i>fire separation</i> of not less than 30 min is acceptable.
58.	A58	3.6.2.2.	Existing acceptable where explosion-resistant <i>construction</i> or venting is provided.
59.	A59	3.6.2.6.	Existing acceptable.
60.	A60	3.6.2.7.(1)	2 h <i>fire separation</i> acceptable.
61.	A61	3.6.3.1.(1) to (5)	45 min <i>fire separation</i> acceptable.
62.	A62	3.6.3.3.(1) to (5) and (8)	Existing acceptable.
63.	A63	3.6.3.3.(9)	1 h acceptable if <i>sprinklered</i> .
64.	A64	3.6.3.3.(10)	Existing acceptable.
65.	A65	3.6.3.4.	Existing acceptable.
66.	A66	3.6.4.	Existing acceptable.
67.	A67	3.7.1.3.(3)	2.1 m is acceptable.
68.	A68	3.7.2.1.(3)	The minimum glass areas may be reduced by 50%.
69.	A69	3.7.4.	Where the <i>occupant load</i> is increased by more than 15% above the capacity of the existing facilities, facilities to be added to accommodate the increase.
70.	A70	3.8.1.2.	Existing accessible entrance

			acceptable. (See C.A. A74) Existing curb ramp conforming to Sentence 3.8.3.2.(3) is acceptable. Existing principal entrance acceptable, provided at least one <i>barrier-free</i> entrance is available.
71.	A71	3.8.1.3.(1)	Existing unobstructed width of 920 mm minimum is acceptable.
72.	A72	3.8.1.3.(4)	Existing unobstructed space not less than 1 500 mm in width and 1 500 mm in length located not more than 30 m apart is acceptable.
72.1	A72.1	3.8.3.2.(3)(b)	Existing curb ramp acceptable, provided width not less than 1 200 mm.
73.	A73	3.8.3.3.(1)	Existing doorway acceptable, provided not less than 810 mm wide.
73.1	A73.1	3.8.3.3.(11)(a)	Existing distance acceptable, provided not less than 1 200 mm plus the width of any door that swings into the space in the path of travel.
74.	A74	3.8.3.4.(1)(a)	Existing ramp acceptable, provided not less than 870 mm between handrails.
75.	A75	3.8.3.8.(5)	Existing grab bar is acceptable.
75.1	A75.1	3.8.3.12.	Existing universal washroom acceptable.
76.	A76	3.8.3.13.(2)(f)	Existing grab bar is acceptable.
76.1	A76.1	3.8.3.16.	Existing drinking fountain conforming to Clauses 3.8.3.16.(2) (a) and (b) acceptable.
76.2	A76.2	3.11.3.1.(9)	Existing clear width acceptable, provided not less than 900 mm.
76.3	A76.3	3.11.3.1.(14)	Existing painted line acceptable.
	<b>NUMBER</b>	<b>PART 4 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
77.	A77	4.1.8.	The requirements under this Subsection do not apply.
	<b>NUMBER</b>	<b>PART 6 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
78.	A78	6.2.2.1.(2)	Required outdoor air rates may be

			provided by mechanical, natural or combination of natural and mechanical means.
	<b>NUMBER</b>	<b>PART 8 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
79.	A79	8.2.1.4.	Existing clearances acceptable where a <i>sewage system</i> is replaced with another <i>sewage system</i> within the same class and the capacity of the replacement <i>sewage system</i> does not exceed the capacity of the existing <i>sewage system</i> .
80.	A80	8.2.1.4.	Existing clearances are acceptable where a replacement <i>sewage system</i> requires lesser clearances than those required in Part 8 for the existing <i>sewage system</i> .

**Table 11.5.1.1.B.****Compliance Alternatives for Care, Care and Treatment or Detention Occupancies**

Forming Part of Article 11.5.1.1.

Item	Col. 1 <b>NUMBER</b>	Column 2 <b>PART 3 REQUIREMENTS</b>	Column 3 <b>PART 11 COMPLIANCE ALTERNATIVE</b>
1.	B1	3.1.5.2. to 3.1.5.4.; 3.1.5.6.	Existing acceptable.
2.	B2	3.1.5.7. to 3.1.5.10.	Except for exposed foamed plastics, existing acceptable.
3.	B3	3.1.5.15. to 3.1.5.17.; 3.1.5.21.; 3.1.5.23.	Existing acceptable.
4.	B4	3.1.7.1.	<i>Fire-resistance ratings</i> may also be used where they are based on:
			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".
			3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".
			4. DBR Technical Paper No. 222,

			“Fire Endurance of Light-Framed and Miscellaneous Assemblies”.
5.	B5	3.1.7.5.(3)	Existing assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
6.	B6	3.1.8.5.(2)	(a) Existing functional and sound doors in existing <i>buildings</i> that are either hollow metal or kalamein and containing wired glass at least 6 mm thick and conforming to Sentence 3.1.8.14.(2) are permitted in lieu of doors not required to exceed 45 min,
			(b) all existing functional and sound hollow metal or kalamein doors which carry existing 1.5 h labels are acceptable in lieu of current 1.5 h labels and may contain wired glass panels not exceeding 0.0645 m <sup>2</sup> , at least 6 mm thick and conforming to Sentence 3.1.8.14.(2), and
			(c) every fire door, window assembly or glass block used as a <i>closure</i> in a required <i>fire separation</i> shall be installed in conformance with good engineering practice.
7.	B7	3.1.8.7. to 3.1.8.9.	<i>Fire dampers</i> or <i>fire stop flaps</i> are not required to be installed in existing ducts at penetrations of existing <i>fire separations</i> .
8.	B8	3.1.8.10.(1)	For existing unlabelled doors in existing <i>buildings</i> , at least 45 mm solid core wood or metal clad are acceptable.
9.	B9	3.1.8.11.(1)	Existing functionally operable self-closing devices acceptable, including devices with “pause” hardware.
10.	B10	3.1.8.12.(1) and (2)	Between patient or inmate rooms, and corridors, existing “pause” type self-closing devices may be used

			as hold-open devices where functionally operable.
11.	B11	3.1.8.13.	Existing functionally operable latching devices, excluding draw bolts, are acceptable.
12.	B12	3.1.8.14.(1) and (2)	Except in zone or <i>exit fire separations</i> not required to be greater than 1 h, existing wired glass installations are acceptable provided they are set in steel or metal clad frames.
13.	B13	3.1.8.14.(3)	Existing glass block acceptable.
14.	B14	3.1.8.15. to 3.1.8.17.	Existing acceptable.
15.	B15	3.1.9.5.(1) and (2)	Existing openings in existing ceiling membranes to remain. Existing openings may be moved to another location in the same ceiling provided the aggregate area of openings does not increase and are not cumulative, and the existing opening is blocked up to provide the same rating as the ceiling assembly.
16.	B16	3.1.11.	Where the concealed space is being materially altered, provide smoke or heat detection in that space in lieu of <i>fire blocks</i> and tie into fire alarm system.
17.	B17	3.1.14.; 3.1.15.	Existing roof assemblies and roof coverings acceptable.
18.	B18	3.2.3.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies no closer than 300 mm from a window in such other <i>building</i> , where the “opposite” window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, to be

			restricted to the same <i>fire compartment</i> and shall conform to the requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
19.	B19	3.2.3.6.(3)	Existing roof soffit projections acceptable.
20.	B20	3.2.4.	(a) Existing fire alarm system may remain except that Article 3.2.4.5. does not apply where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as required, Fire Department connection and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
21.	B21	3.2.4.9.(2)(e)	Does not apply to existing installations in <i>buildings</i> .
22.	B22	3.2.4.10.(5)(c)	Does not apply to existing installations in <i>buildings</i> .
23.	B23	3.2.5.1.; 3.2.5.2.	Existing access to an existing <i>occupancy</i> acceptable.
			Where the existing <i>building</i> is changed to a “B” <i>occupancy</i> ,

			existing access are acceptable.
24.	B24	3.2.5.3.(1)	Existing acceptable, except where a change in <i>occupancy</i> occurs to a “B1” or “B2” <i>occupancy</i> .
25.	B25	3.2.5.3.(2)	Existing acceptable.
26.	B26	3.2.5.4. to 3.2.5.6.	Existing access route to existing <i>occupancy</i> is acceptable if the <i>building</i> is <i>sprinklered</i> .
			Where existing <i>building</i> is changed to a “B” <i>occupancy</i> , access route shall be provided.
27.	B27	3.2.5.7.; 3.2.5.18.	Does not apply except where a change in <i>occupancy</i> occurs to a “B1” or “B2” <i>occupancy</i> , where occupants are not normally evacuated from the <i>building</i> .
28.	B28	3.2.5.13.	Existing sprinkler systems in existing <i>buildings</i> that do not conform to NFPA 13 may be altered, added to, or extended from the existing system without complying with NFPA 13, provided the system is operational and adequate with respect to coverage, water supply and controls, and provided the system is evaluated by a qualified designer.
29.	B29	3.2.9.	Does not apply except where a change in <i>occupancy</i> occurs to a Group B <i>occupancy</i> , where occupants are not normally evacuated from the <i>building</i> .
30.	B30	3.3.1.9.	Existing width of <i>public corridors</i> of not less than 914 mm is acceptable, except as provided in Sentence 3.3.3.3.(2).
31.	B31	3.3.1.10.; 3.3.1.11.	Existing door swings may remain in <i>heritage buildings</i> , existing or being restored, with no change in <i>major occupancy</i> and with <i>occupant load</i> no greater than 100.
32.	B32	3.3.1.12.	Existing doors acceptable.
33.	B33	3.3.1.15.	Existing acceptable.
34.	B34	3.3.1.16.	Existing non-conforming capacities of <i>access to exits</i> are acceptable,



			provided that the excessive capacity is no greater than 15% and,
			(a) corridor <i>fire separations</i> are rated to Code plus early warning system provided, or
			(b) there are sprinklers, plus <i>smoke alarms</i> in <i>suites</i> .
35.	B35	3.3.1.17.	Existing acceptable.
36.	B36	3.3.1.18.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
37.	B37	3.3.3.3.(1)	Existing dead end corridors acceptable with 30 min <i>fire separation</i> of corridor plus sprinklering of <i>floor area</i> , provided the <i>occupant load</i> is not greater than 10 persons and travel distance not greater than 6 m plus corridor width to “ <i>exit choice</i> ” point.
38.	B38	3.3.3.7.	45 min <i>fire separation</i> acceptable.
39.	B39	3.3.5.4.(1); 3.3.5.7.(3)	Need not comply where a gasketed door and self closer are provided in the existing <i>fire separation</i> .
40.	B40	3.4.1.8.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
41.	B41	3.4.2.5.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> and provided <i>fire separations</i> comply with Part 3.
42.	B42	3.4.3.2.(7)	Existing acceptable provided there is no change in <i>occupancy</i> to a “B2” or “B3”.
43.	B43	3.4.3.4.	Existing acceptable.
44.	B44	3.4.3.5.	Existing headroom clearance of not less than 1 980 mm is acceptable.
45.	B45	3.4.5.1.(2) and (9)	Existing illuminated legible <i>exit</i> signs are acceptable.
46.	B46	3.4.6.2.	Existing acceptable, if visually apparent.
47.	B47	3.4.6.3.(1)	Existing acceptable with rise no greater than 3.7 m.
48.	B48	3.4.6.4.(1)	Existing acceptable provided there is no change in <i>occupancy</i> to a

			"B2" or "B3".
49.	B49	3.4.6.4.(2) to (4)	Existing acceptable.
50.	B50	3.4.6.5.(2) to (11)	Existing acceptable.
51.	B51	3.4.6.6.(2) to (5)	Existing acceptable.
52.	B52	3.4.6.7.(1)	Existing acceptable.
53.	B53	3.4.6.8.	Existing acceptable.
54.	B54	3.4.6.9.	Existing acceptable where there is no change in <i>major occupancy</i> or increase in <i>occupant load</i> greater than 15%.
55.	B55	3.4.6.11.(1), (2) and (4)	Existing acceptable.
56.	B56	3.4.6.12.	Existing acceptable in <i>public heritage buildings</i> .
57.	B57	3.4.6.16.(2) and (3)	Existing functionally operable panic hardware acceptable.
58.	B58	3.4.6.18.(1)(c)	Existing access to existing <i>occupancy</i> is acceptable Where the existing <i>building</i> is changed to a "B" <i>occupancy</i> , existing access is acceptable.
59.	B59	3.4.7.2.	<i>Combustible</i> fire escapes which are protected from fire in accordance with Sentence 3.2.3.14.(2) are permitted or may be reconstructed or recreated (as in the case of a <i>heritage building</i> ). Where serving non-ambulatory persons, minimum width shall be 1 100 mm.
60.	B60	3.5.1.	Existing acceptable, except where <i>building</i> is classified under Subsection 3.2.6.
61.	B61	3.6.2.1.(7)	45 min <i>fire separation</i> acceptable.
62.	B62	3.6.2.6.	Existing acceptable.
63.	B63	3.6.2.7.(1)	2 h <i>fire separation</i> acceptable.
64.	B64	3.6.3.1.(1) to (5)	45 min <i>fire separation</i> acceptable.
65.	B65	3.6.3.3.(1), (3), (4) (a), (5) and (10)	Existing acceptable.
66.	B66	3.6.3.3.(2)(a)	45 min <i>fire separation</i> acceptable.
67.	B67	3.6.4.	Existing acceptable, except where a change in <i>occupancy</i> occurs to a Group B <i>occupancy</i> .
68.	B68	3.7.1.3.(1)	Existing acceptable.

69.	B69	3.7.2.1.(2)	The minimum glass areas may be reduced by 50%.
70.	B70	3.7.4.	Where the <i>occupant load</i> is increased by more than 15% above the capacity of the existing facilities, facilities to be added to accommodate the increase.
71.	B71	3.8.1.2.	Existing accessible entrance acceptable. (See C.A. B75) Existing curb ramp conforming to Sentence 3.8.3.2.(3) is acceptable. Existing principal entrance acceptable, provided at least one <i>barrier-free</i> entrance is available.
72.	B72	3.8.1.3.(1)	Existing unobstructed width of 920 mm minimum is acceptable.
73.	B73	3.8.1.3.(4)	Existing unobstructed space not less than 1 500 mm in width and 1 500 mm in length located not more than 30 m apart is acceptable.
73.1	B73.1	3.8.3.2.(3)(b)	Existing curb ramp acceptable, provided width not less than 1 200 mm.
74.	B74	3.8.3.3.(1)	Existing doorway acceptable, provided not less than 810 mm wide.
74.1	B74.1	3.8.3.3.(11)(a)	Existing distance acceptable, provided not less than 1 200 mm plus the width of any door that swings into the space in the path of travel.
75.	B75	3.8.3.4.(1)(a)	Existing ramp acceptable, provided not less than 870 mm between handrails.
76.	B76	3.8.3.8.(5)	Existing grab bar is acceptable.
76.1	B76.1	3.8.3.12.	Existing universal washroom acceptable.
77.	B77	3.8.3.13.(2)(f)	Existing grab bar is acceptable.
77.1	B77.1	3.8.3.16.	Existing drinking fountain conforming to Clauses 3.8.3.16.(2) (a) and (b) acceptable.
77.2	B77.2	3.11.3.1.(9)	Existing clear width acceptable, provided not less than 900 mm.

77.3	B77.3	3.11.3.1.(14)	Existing painted line acceptable.
	<b>NUMBER</b>	<b>PART 4 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
78.	B78	4.1.8.	The requirements under this Subsection do not apply.
	<b>NUMBER</b>	<b>PART 6 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
79.	B79	6.2.2.1.(2)	Required outdoor air rates may be provided by mechanical, natural or combination of natural and mechanical means.
	<b>NUMBER</b>	<b>PART 8 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
80.	B80	8.2.1.4.	Existing clearances acceptable where a <i>sewage system</i> is replaced with another <i>sewage system</i> within the same class and the capacity of the replacement <i>sewage system</i> does not exceed the capacity of the existing <i>sewage system</i> .
81.	B81	8.2.1.4.	Existing clearances are acceptable where a replacement <i>sewage system</i> requires lesser clearances than those required in Part 8 for the existing <i>sewage system</i> .

**Table 11.5.1.1.C. Compliance Alternatives for Residential Occupancies**

Forming Part of Article 11.5.1.1.

Item	Col. 1 <b>NUMBER</b>	Column 2 <b>PART 3 REQUIREMENTS</b>	Column 3 <b>PART 11 COMPLIANCE ALTERNATIVE</b>
1.	C1	3.1.4.7.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of member sizes listed in Part 3.
2.	C2	3.1.5.2. to 3.1.5.4.; 3.1.5.6.	Existing acceptable.
3.	C3	3.1.5.7. to 3.1.5.10.	Except for exposed foamed plastics, existing acceptable. To match existing, materials may be added from on or off site.
4.	C4	3.1.5.14. to 3.1.5.17.;	Existing acceptable.

		3.1.5.21.; 3.1.5.23.	
5.	C5	3.1.7.1.	<i>Fire-resistance ratings</i> may also be used where they are based on: <ol style="list-style-type: none"> <li>1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".</li> <li>2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".</li> <li>3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".</li> <li>4. DBR Technical Paper No. 222, "Fire Endurance of Light-Framed and Miscellaneous Assemblies".</li> </ol>
6.	C6	3.1.7.5.(3)	Existing assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
7.	C7	3.1.8.1.(2); 3.1.8.6.(1) and (2)	Existing functional <i>closures</i> are acceptable and may be relocated within the same existing <i>fire separation</i> .
8.	C8	3.1.8.5.(2)	(a) Existing functional and sound doors in existing <i>buildings</i> that are either hollow metal or kalamein and containing wired glass at least 6 mm thick and conforming to Sentence 3.1.8.14.(2) are permitted in lieu of doors not required to exceed 45 min,  (b) all existing functional and sound hollow metal or kalamein doors which carry existing 1.5 h labels are acceptable in lieu of current 1.5 h labels and may contain wired glass panels not exceeding 0.0645 m <sup>2</sup> , at least 6 mm thick and conforming to Sentence 3.1.8.14.(2), and  (c) every fire door, window assembly or glass block used as a <i>closure</i> in a required <i>fire separation</i> shall be installed in conformance with good engineering practice.
9.	C9	3.1.8.7. to 3.1.8.9.	Except for <i>hotels</i> , <i>fire dampers</i> or <i>fire stop flaps</i> are not required to be installed in existing ducts at penetrations of existing <i>fire separations</i> .

10.	C10	3.1.8.10.(1)	For existing unlabeled doors in existing <i>buildings</i> , at least 45 mm solid core wood or metal clad are acceptable. Except for <i>residential occupancies</i> , existing closure rating of 20 min will not be required where the entire <i>floor area</i> is <i>sprinklered</i> .
10.1	C10.1	3.1.8.12.(1) and (2)	In <i>retirement homes</i> , between a <i>suite</i> and a <i>public corridor</i> , existing 'pause' type self-closing devices may be used as hold-open devices where functionally operable.
11.	C11	3.1.8.13.	Existing functionally operable latching devices, excluding draw bolts, are acceptable.
12.	C12	3.1.8.14.	Existing transoms or sidelights located in <i>fire separations</i> not required to be greater than 1 h may be retained if wired glass, at least 6 mm thick, is securely fixed to a wood frame of at least 50 mm thickness with steel stops. Operable transoms shall be fixed closed.
13.	C13	3.1.8.15. to 3.1.8.17.	Existing acceptable.
14.	C14	3.1.11.	Where the concealed space is being materially altered, provide smoke or heat detection in that space in lieu of <i>fire blocks</i> and tie into fire alarm system.
15.	C15	3.2.2.17.(1)(b) and (c)	Except for <i>retirement homes</i> , existing sprinkler systems in 1 <i>storey buildings</i> need not comply.
16.	C16	3.2.3.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies not closer than 300 mm from a window in such other <i>building</i> , where the "opposite" window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, shall be restricted to the same <i>fire compartment</i> and shall conform to the

			requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
17.	C17	3.2.3.6.(3)	Existing roof soffit projections acceptable.
18.	C18	3.2.4.	(a) Existing fire alarm system may remain except that Article 3.2.4.5. does not apply where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as required, Fire Department connection, and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
19.	C19	3.2.4.9.(2)(e)	Does not apply to existing installations in <i>buildings</i> .
20.	C20	3.2.4.10.(5)(c)	Does not apply to existing installations in <i>buildings</i> .
21.	C21	3.2.4.22.	Except for <i>retirement homes</i> , such <i>smoke alarms</i> may be battery operated.
22.	C22	3.2.5.1.; 3.2.5.2.	Existing acceptable.
23.	C23	3.2.5.3.(1)	Existing access acceptable.
24.	C24	3.2.5.3.(2)	Existing acceptable.
25.	C25	3.2.5.4. to 3.2.5.6.	(a) For <i>buildings</i> 6 storeys and less, existing access to existing <i>occupancy</i> is acceptable, and
			(b) where existing <i>building</i> is changed to a “C” <i>occupancy</i> , an access route shall be provided, or the existing access is acceptable provided the <i>building</i> is <i>sprinklered</i> .

26.	C26	3.2.5.7.	Existing water supply and hydrants are acceptable in <i>buildings</i> up to 6 <i>storeys</i> in <i>building height</i> .
27.	C27	3.2.5.13.	Existing sprinkler systems in existing <i>buildings</i> that do not conform to NFPA 13 may be altered, added to, or extended from the existing system without complying with NFPA 13, provided the system is operational and adequate with respect to coverage, water supply and controls, and provided the system is evaluated by a qualified designer.
28.	C28	3.2.9.	Does not apply to <i>buildings</i> 4 <i>storeys</i> and less. For existing <i>buildings</i> over 4 <i>storeys</i> in <i>building height</i> , existing standpipe and hose systems water supply is acceptable provided it can deliver a minimum flow rate of 265 L/min for 30 min at 345 kPa (gauge) at the two highest and most remote hose valves, with not less than 132 L/min from each of the two simultaneously.
29.	C29	3.3.1.4.(1); 3.3.4.2.(1)	30 min is acceptable to separate corridors or <i>exits</i> in <i>buildings</i> not exceeding 6 <i>storeys</i> in <i>building height</i> , except that 45 min is required for <i>exits</i> in <i>buildings</i> exceeding 3 <i>storeys</i> in <i>building height</i> . For <i>buildings</i> exceeding 6 <i>storeys</i> in <i>building height</i> , 30 min is acceptable where <i>smoke detectors</i> are installed in corridors, except 1 h is required in <i>exits</i> . 30 min is acceptable to separate <i>public corridors</i> , <i>exits</i> or <i>suites</i> in <i>hotels</i> , provided <i>fire detectors</i> are installed in every room in a <i>suite</i> and in every room not located in a <i>suite</i> , other than corridors, washrooms, closets in <i>suites</i> , saunas, refrigerated areas and swimming pools.
30.	C30	3.3.1.5.(1)(c); Tables 3.3.1.5.A. and 3.3.1.5.B.	In Column 2, maximum area of room or <i>suite</i> to be unlimited.
31.	C31	3.3.1.9.	Existing width of <i>public corridors</i> of not less than 914 mm is acceptable.
32.	C32	3.3.1.10.;	Existing door swings may remain



		3.3.1.11.	in <i>heritage buildings</i> , existing or being restored, with no change in <i>major occupancy</i> and with <i>occupant load</i> no greater than 100.
33.	C33	3.3.1.12.	Existing doors acceptable, provided not less than 600 mm wide.
34.	C34	3.3.1.15.	Existing curved or spiral stairs acceptable.
35.	C35	3.3.1.16.	Existing non-conforming capacities of <i>access to exits</i> are acceptable, provided that the excessive capacity is no greater than 15% and,
			(a) corridor <i>fire separations</i> are rated to Code plus early warning system provided, or
			(b) there are sprinklers, plus <i>smoke alarms</i> in <i>suites</i> .
36.	C36	3.3.1.17.	Does not apply to <i>heritage buildings</i> .
37.	C37	3.3.1.18.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
38.	C38	3.3.4.2.(3)(b)(i)	30 min <i>fire separation</i> acceptable.
		3.3.4.2.(3)(b)(ii), (iii)	45 min <i>fire separation</i> acceptable.
		3.3.4.2.(3)(b)(iv)	1.5 h <i>fire separation</i> acceptable.
39.	C39	3.3.4.4.(4) and (5)	For <i>buildings</i> 6 <i>storeys</i> and less, doorway from <i>dwelling unit</i> will be permitted to open directly into <i>exit</i> stairway or interior corridor served by a single <i>exit</i> if a fire alarm system complying with Subsection 3.2.4. is installed and the <i>dwelling unit</i> has a second and separate <i>means of egress</i> .
40.	C40	3.3.5.4.(1) and 3.3.5.7.(3)	Need not comply where a gasketed door and self closer are provided in the existing <i>fire separation</i> .
41.	C41	3.4.1.4.	Except for <i>hotels</i> and <i>retirement homes</i> , the following types of <i>exits</i> may also be used for <i>buildings</i> not over 6 <i>storeys</i> in <i>building height</i> :
			(a) connected balconies, which connect across <i>firewalls</i> , or connect to another <i>exit</i> , or with access to ground level,
			(b) areas of refuge where fire service rescue is possible and that comply with Measure L of Sentences (4) to (10), (18) and Clauses (20)(a), (b) and (d) in MMAH

			Supplementary Standard SB-4, "Measures for Fire Safety in High Buildings".
42.	C42	3.4.1.8.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
43.	C43	3.4.2.5.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> and provided <i>fire separations</i> comply with Part 3.
44.	C44	3.4.3.2.(7)	Existing width of <i>exits</i> acceptable provided the <i>occupant load</i> is not more than 15% above the <i>exit capacity</i> .
45.	C45	3.4.3.4.	Except for <i>heritage buildings</i> , existing acceptable, provided not less than 800 mm.
46.	C46	3.4.3.5.	Existing headroom clearance of not less than 1 980 mm is acceptable.
47.	C47	3.4.4.1.(1)	Except for <i>exits</i> , no rating required where <i>floor areas</i> are <i>spinklered</i> .
48.	C48	3.4.4.1.	<i>Fire separations</i> of <i>exits</i> permitted in <i>buildings</i> :
			- 30 min, up to 3 <i>storeys</i> in <i>building height</i> ;
			- 45 min, in <i>hotels</i> up to 3 <i>storeys</i> in <i>building height</i> ;
			- 45 min, up to 6 <i>storeys</i> in <i>building height</i> ;
			- 1 h, over 6 <i>storeys</i> in <i>building height</i> .
49.	C49	3.4.4.4.(8)	Existing washrooms opening directly into an <i>exit</i> stairwell shall be separated from the <i>exit</i> stairwell by a 45 min <i>closure</i> .
50.	C50	3.4.5.1.(2) and (9)	Existing illuminated legible <i>exits</i> signs are acceptable.
51.	C51	3.4.6.1.	Existing acceptable.
52.	C52	3.4.6.2.	Existing acceptable, if visually apparent.
53.	C53	3.4.6.3.(1)	Existing acceptable with rise no greater than 3.7 m.
54.	C54	3.4.6.4.(1)	Existing acceptable.
55.	C55	3.4.6.4.(2) and (3)	Existing acceptable.
56.	C56	3.4.6.5.(2) and (11)	Existing acceptable.
57.	C57	3.4.6.6.(2) and (4)	Existing acceptable.
58.	C58	3.4.6.7.(1)	Existing acceptable.
59.	C59	3.4.6.8.	Existing acceptable.
60.	C60	3.4.6.9.	(a) Except for <i>retirement homes</i> , existing acceptable.

			(b) For <i>retirement homes</i> , existing acceptable provided there is no change in <i>major occupancy</i> or increase in <i>occupant load</i> greater than 15%.
61.	C61	3.4.6.10.(2) to (6)	Existing acceptable.
62.	C62	3.4.6.11.(1) and (2)	Existing acceptable.
63.	C63	3.4.6.12.	Existing acceptable in <i>heritage buildings</i> provided the <i>occupant load</i> is not more than 60.
64.	C64	3.4.6.16.(1) to (3)	Existing functionally operable panic hardware acceptable.
65.	C65	3.4.7.2.	Except for <i>retirement homes</i> , <i>combustible</i> fire escapes which are protected from fire in accordance with Sentence 3.2.3.13.(2) are permitted or may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
66.	C66	3.5.1.	Existing acceptable except where <i>building</i> is classified under Subsection 3.2.6.
67.	C67	3.6.2.1.(7)	45 min <i>fire separation</i> acceptable.
68.	C68	3.6.2.2.	Existing acceptable where explosion-resistant <i>construction</i> or venting is provided.
69.	C69	3.6.2.6.	Existing acceptable.
70.	C70	3.6.2.7.(1)	2 h <i>fire separation</i> acceptable.
71.	C71	3.6.3.1.(1) to (5)	45 min <i>fire separation</i> acceptable up to 6 <i>storeys</i> .
72.	C72	3.6.3.3.(2)	Where 2 h <i>fire separation</i> is required, 1 h is acceptable. Except for linen discharge rooms where 1 h <i>fire separation</i> is required, 45 min is acceptable.
73.	C73	3.6.3.3.(4) and (5)	Existing sizes acceptable.
74.	C74	3.6.3.3.(9)	Where 2 h <i>fire separation</i> is required, 1 h is acceptable.
75.	C75	3.6.4.2.	Except for <i>retirement homes</i> , ceiling <i>fire separation</i> need not have a <i>fire-resistance rating</i> where sprinklering, subject to C.A. C27, of <i>fire compartment</i> on both sides of vertical <i>fire separation</i> is provided and where such <i>fire separation</i> is not required to exceed 1 h.
76.	C76	3.6.4.3.(1)	Existing to meet <i>flame-spread rating</i> of 25

			or to be <i>sprinklered</i> .
77.	C77	3.6.4.4. to 3.6.4.6.	Existing access acceptable.
78.	C78	3.7.1.1.(2)	Minimum room height shall be not less than 1 950 mm over the required floor area and any location that would normally be used as a <i>means of egress</i> .
79.	C79	3.7.2.1.	(a) Where windows are not used as <i>means of egress</i> and where they do not conflict with ventilation requirements, the minimum glass areas as shown in Table 9.7.2.3. may be reduced by 50%, or
			(b) an existing room converted to an interior room, created by an addition, shall not require a window, provided there is an opening in a dividing wall occupying not less than 30% of the separating plane to an adjoining room, where the adjoining room has a minimum of 5% window area of the combined floor areas, and provided the required ventilation for the combined room is maintained.
80.	C80	3.7.4.	Where the <i>occupant load</i> is increased by more than 15% above the capacity of the existing facilities, facilities to be added to accommodate the increase.
81.	C81	3.8.1.2.	Existing accessible entrance acceptable. (see C.A. C85) Existing curb ramp conforming to Sentence 3.8.3.2.(3) is acceptable. Existing principal entrance acceptable, provided at least one <i>barrier-free</i> entrance is available.
82.	C82	3.8.1.3.(1)	Existing unobstructed width of 920 mm minimum is acceptable.
83.	C83	3.8.1.3.(4)	Existing unobstructed space not less than 1 500 mm in width and 1 500 mm in length located not more than 30 m apart is acceptable.
83.1	C83.1	3.8.3.2.(3)(b)	Existing curb ramp acceptable, provided width not less than 1 200 mm.
84.	C84	3.8.3.3.(1)	Existing doorway acceptable, provided not less than 810 mm wide.
84.1	C84.1	3.8.3.3.(11)(a)	Existing distance acceptable, provided not less than 1 200 mm plus the width of any door that swings into the space in the path of travel.

85.	C85	3.8.3.4.(1)(a)	Existing ramp acceptable, provided not less than 870 mm between handrails.
86.	C86	3.8.3.8.(5)	Existing grab bar is acceptable.
86.1	C86.1	3.8.3.12.	Existing universal washroom acceptable.
87.	C87	3.8.3.13.(2)(f)	Existing grab bar is acceptable.
87.1	C87.1	3.8.3.16.	Existing drinking fountain conforming to Clauses 3.8.3.16.(2)(a) and (b) acceptable.
87.2	C87.2	3.11.3.1.(9)	Existing clear width acceptable, provided not less than 900 mm.
87.3	C87.3	3.11.3.1.(14)	Existing painted line acceptable.
	<b>NUMBER</b>	<b>PART 4 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
88.	C88	4.1.8.	The requirements under this Subsection do not apply.
	<b>NUMBER</b>	<b>PART 6 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
89.	C89	6.2.2.1.(2)	Required outdoor air rates may be provided by mechanical, natural or combination of natural and mechanical means.
90.	C90	6.2.3.2.; 6.2.3.8.; 6.2.3.18; 6.2.3.19.	Existing acceptable.
91.	C91	6.2.3.9.(1)	In a <i>building</i> containing not more than four <i>dwelling units</i> or residential <i>suites</i> , the existing heating or <i>air-conditioning</i> system may be altered to serve more than one <i>dwelling unit</i> or <i>suite</i> , provided <i>smoke alarms</i> are installed in each <i>dwelling unit</i> or <i>suite</i> and provided a <i>smoke detector</i> is installed in the supply or return air duct system serving the entire <i>building</i> which would turn off the fuel supply and electrical power to the heating system upon activation of such detector.
92.	C92	6.2.3.12.	Existing openings, grilles and diffusers acceptable.
93.	C93	6.2.4.2.(1); 6.2.4.3.(1) to (3), (5), (11) and (12)	Existing acceptable.
94.	C94	6.2.4.3.(10)	Where the duct system is being altered, lesser amounts and extent of insulation will be permitted.
95.	C95	6.2.4.7.(10)	In a <i>building</i> containing not more than four <i>dwelling units</i> or residential <i>suites</i> , the

			existing heating or <i>air-conditioning</i> system may be altered to serve more than one <i>dwelling unit</i> or <i>suite</i> , provided <i>smoke alarms</i> are installed in each <i>dwelling unit</i> or <i>suite</i> and provided a <i>smoke detector</i> is installed in the supply or return air duct system serving the entire <i>building</i> which would turn off the fuel supply and electrical power to the heating system upon activation of such detector.
96.	C96	6.2.9.2.	Existing acceptable.
97.	C97	6.2.12.3.(1)	Carbon monoxide alarms may be battery operated or plugged into an electrical outlet.
98.	C98	6.3.1.	Existing acceptable, provided products of combustion are safely vented.
	<b>NUMBER</b>	<b>PART 8 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
99.	C99	8.2.1.4.	Existing clearances acceptable where a <i>sewage system</i> is replaced with another <i>sewage system</i> within the same class and the capacity of the replacement <i>sewage system</i> does not exceed the capacity of the existing <i>sewage system</i> .
100.	C100	8.2.1.4.	Existing clearances are acceptable where a replacement <i>sewage system</i> requires lesser clearances than those required in Part 8 for the existing <i>sewage system</i> .
	<b>NUMBER</b>	<b>PART 9 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
101.	C101	9.3.2.1.	Sound used lumber may be acceptable for reuse without a grade stamp provided that:
			(a) visual examination shows no excessive weakening by holes, notches, nail splits or other damage,
			(b) where the grade or species is unknown, the minimum grade shall apply for span table use, and
			(c) lumber has not been subjected to termite infestation.
102.	C102	9.5.3.1.	In a <i>house</i> , (a) minimum room height shall not be less than 1 950 mm over the required floor

			area and in any location that would normally be used as a <i>means of egress</i> , or (b) minimum room height shall not be less than 2 030 mm over at least 50% of the required floor area, provided that any part of the floor having a clear height of less than 1 400 mm shall not be considered in computing the required floor area.
103.	C103	9.5.11.1.	Doors may be lesser heights to suit ceiling heights.
104.	C104	9.5.11.2.	Existing acceptable, provided not less than 600 mm.
105.	C105	9.6.1.2.(2) and (3); 9.6.1.4.(1) and (2)	Existing doors and sidelights being reused or relocated need not conform if identified or protected.
106.	C106	9.6.1.4.(3)	Existing acceptable, if marked to indicate their existence and position.
107.	C107	9.7.2.3.	(a) Where windows are not used as a <i>means of egress</i> and where they do not conflict with ventilation requirements, the minimum glass areas as shown in Table 9.7.2.3. may be reduced by 50%, and  (b) an existing room converted to an interior room, created by an addition, shall not require a window, provided there is an opening in a dividing wall occupying not less than 30% of the separating plane to an adjoining room, where the adjoining room has a minimum of 5% window area of the combined floor areas, and provided the required ventilation for the combined room is maintained.
108.	C108	9.7	Existing acceptable.
109.	C109	9.8.1. to 9.8.4.	Replacement or extension of existing stair systems shall be exempt from the provisions of these Subsections, except that they shall have:  (a) a minimum width between wall faces of 700 mm, and  (b) a minimum clear height over tread nosing or landing of 1 800 mm.
110.	C110	9.8.4.3.	Existing curved or spiral stairs are acceptable.
111.	C111	9.8.4.5.	Where a stair complies with Subsection 9.8.4., an extension to a stair may contain two sets of winders provided that they are

			separated by at least three treads or a landing.
112.	C112	9.8.5.1.(2)	Existing ramps acceptable, where practical.
113.	C113	9.8.7.	Existing handrails acceptable, unless considered unsafe by <i>chief building official</i> .
114.	C114	9.8.8.	Existing <i>guards</i> acceptable, unless considered unsafe by <i>chief building official</i> .
115.	C115	9.8.9.6.(4)	Existing acceptable.
116.	C116	9.9.2.1.(1) to (3)	Except for <i>hotels</i> , the following types of <i>exits</i> may also be used:
			(a) connected balconies, which connect across <i>firewalls</i> , or connect to another <i>exit</i> , or with access to grade,
			(b) areas of refuge approved by the <i>chief building official</i> , where fire service rescue is possible, or
			(c) <i>combustible</i> or <i>noncombustible</i> exterior stairways or fire escapes which are protected in accordance with Sentence 3.2.3.13.(2). These may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
117.	C117	9.9.2.1.(4)	Except for <i>hotels</i> , existing acceptable.
118.	C118	9.9.3.2.	(a) In a <i>building</i> containing not more than four <i>dwelling units</i> , the width of every <i>exit</i> facility may be as the existing, but not less than 800 mm, or
			(b) in a <i>building</i> containing more than four <i>dwelling units</i> , the width of every <i>exit</i> facility may be as the existing, but not less than 900 mm.
119.	C119	9.9.3.3.	(a) In a <i>building</i> containing not more than four <i>dwelling units</i> , the minimum width of a <i>public corridor</i> may be 800 mm, or
			(b) in a <i>building</i> containing more than four <i>dwelling units</i> , the minimum width of a <i>public corridor</i> may be 900 mm.
120.	C120	9.9.3.4.	Existing clear height of not less than 1 950 mm is acceptable.
121.	C121	9.9.4.2.	Except as permitted in C.A.C136, in a <i>building</i> containing not more than four <i>dwelling units</i> or <i>suites</i> , one <i>exit</i> need



			not be separated from the remainder of the <i>building</i> at the <i>first storey</i> where there are one or more other <i>exits</i> complying with C.A.C122.
122.	C122	9.9.4.2.(1) and (2)	30 min <i>fire separation</i> acceptable.
123.	C123	9.9.5.4.	Existing acceptable.
124.	C124	9.9.5.8.	Existing acceptable provided minimum 45 min <i>fire separation</i> and where explosion-resistant <i>construction</i> or venting is provided.
125.	C125	9.9.5.9.	Existing acceptable, provided that the enclosure has a 45 min <i>fire-resistance rating</i> .
126.	C126	9.9.6.1.	Except for <i>hotels</i> , existing acceptable.
127.	C127	9.9.6.2.	Existing clear opening height of not less than 1 950 mm is acceptable.
128.	C128	9.9.6.3.	Existing door widths are acceptable, provided <i>exit</i> widths conform to C.A. C118.
129.	C129	9.9.6.5.	Existing door swings acceptable.
			Existing acceptable in <i>public heritage buildings</i> , where approved by <i>chief building official</i> .
130.	C130	9.9.6.6.(1)	Where <i>exit</i> doors open onto a landing, they shall not extend beyond the face of the first riser.
131.	C131	9.9.6.8.	Existing functionally operable passage or panic hardware acceptable.
132.	C132	9.9.7.4.(1)(a)	Maximum area of existing room or <i>suite</i> does not apply.
133.	C133	9.9.7.5.	Except as provided in C.A.C136, in a <i>house</i> , the Code requirement applies.
134.	C134	9.9.8.2.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> and provided <i>fire separations</i> comply with Part 9.
135.	C135	9.9.8.5.	In a <i>building</i> containing not more than four <i>dwelling units</i> or <i>suites</i> , existing glazed solid wood doors to lobby may remain in lieu of new 20 minute doors, provided the <i>fire separations</i> for the floor above or below are provided as per C.A. C147, and a second <i>means of egress</i> from the <i>dwelling units</i> complies with the Code requirements.
136.	C136	9.9.9.	In a <i>house</i> , <i>exit</i> requirements are

acceptable if at least one of the following conditions exists:

- (a) a door, including a sliding door, that opens directly to the exterior from a *dwelling unit*, serves only that *dwelling unit* and has reasonable access to ground level, and the *dwelling units* are equipped with *smoke alarms* installed in conformance with Subsection 9.10.19.,
- (b) an *exit* that is accessible to more than one *dwelling unit* and provides the only *means of egress* from each *dwelling unit*, provided that the *means of egress* is separated from the remainder of the *building* and common areas by a *fire separation* having a 30 min *fire-resistance rating* and provided further that the required *access to exit* from any *dwelling unit* cannot be through another *dwelling unit*, *service room* or other *occupancy*, and both *dwelling units* and common areas are provided with *smoke alarms* that are installed in conformance with Subsection 9.10.19. and are interconnected, or
- (c) access to an *exit* from one *dwelling unit* which leads through another *dwelling unit* where,
  - (i) an additional means of escape is provided through a window that conforms to the following:
    - (A) the sill height is not more than 1 000 mm above or below adjacent ground level,
    - (B) the window can be opened from the inside without the use of tools,
    - (C) the window has an individual unobstructed open portion having a minimum area of 0.38 m<sup>2</sup> with no dimension less than 460 mm,
    - (D) the sill height does not exceed 900 mm above the floor or fixed steps,
    - (E) where the window opens into a window well, a clearance of not less than 1 000 mm shall be provided in front of the window, and

			<p>(F) <i>smoke alarms</i> are installed in every <i>dwelling unit</i> and in common areas in conformance with Subsection 9.10.19. and are interconnected,</p> <p>(ii) an additional means of escape is provided through a window that conforms to the following:</p> <p>(A) the window is a casement window not less than 1 060 mm high, 560 mm wide, with a sill height not more than 900 mm above the inside floor,</p> <p>(B) the sill height of the window is not more than 5 m above adjacent ground level, and</p> <p>(C) <i>smoke alarms</i> are installed in every <i>dwelling unit</i> and in common areas in conformance with Subsection 9.10.19. and are interconnected, or</p> <p>(iii) the <i>building</i> is <i>sprinklered</i> and the <i>dwelling units</i> are equipped with <i>smoke alarms</i> installed in conformance with Subsection 9.10.19.</p>
137.	C137	9.9.10.1.	In a <i>house</i> , existing acceptable, where there is direct access to the exterior.
138.	C138	9.9.11.	In a <i>house</i> , the requirements under this Subsection do not apply.
139.	C139	9.9.11.3.	Existing illuminated legible signs are acceptable for <i>exit</i> signs, if approved by <i>chief building official</i> .
140.	C140	9.9.12.	In a <i>house</i> , the requirements under this Subsection apply only where the condition described in (b) of C.A. C136 exists.
141.	C141	9.10.1.1.	Assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
142.	C142	9.10.1.3.(8) to (10)	Existing installations acceptable subject to C.A.'s C26, C27 and C28.
143.	C143	9.10.3.	<i>Fire-resistance ratings</i> may also be used where they are based on:

			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".
			3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".
			4. DBR Technical Paper No. 222, "Fire Endurance of Light-Framed and Miscellaneous Assemblies".
144.	C144	9.10.5.1.	(a) Existing openings in existing wall or ceiling membranes to remain.
			(b) Existing openings may be moved to another location in the same wall or ceiling, provided the aggregate area of openings does not increase and are not cumulative, and the existing opening is blocked up to provide the same rating as the existing wall or ceiling assembly.
145.	C145	9.10.6.2.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of member sizes listed in Part 3.
146.	C146	9.10.7.	Existing acceptable for <i>heritage buildings</i> , subject to approval of <i>chief building official</i> .
147.	C147	9.10.8.1.; 9.10.8.3.; 9.10.8.8.	(a) Except as provided in (b) and (c), 30 min rating is acceptable. (b) In a <i>house</i> , 15 min horizontal <i>fire separation</i> is acceptable where, (i) <i>smoke alarms</i> are installed in every <i>dwelling unit</i> and in common areas in conformance with Subsection 9.10.19., and (ii) <i>smoke alarms</i> are interconnected. (c) In a <i>house</i> , the <i>fire-resistance rating</i> of the <i>fire separation</i> is waived where the <i>building</i> is <i>sprinklered</i> .
148.	C148	9.10.9.7.; 9.10.9.9.	Existing acceptable in existing <i>fire separations</i> .
149.	C149	9.10.9.10.(1)	Ceiling <i>fire separation</i> need not have a <i>fire-resistance rating</i> where sprinklering, subject to C.A. C27, of <i>fire compartments</i> on both sides of vertical <i>fire</i>

			<i>separation</i> is provided and where such <i>fire separation</i> is not required to exceed 1 h.
150.	C150	9.10.9.11.(1)	Except for <i>hotels</i> , 30 min <i>fire separation</i> acceptable.
151.	C151	9.10.9.11.(2)	In lieu of the 2 h <i>fire separation</i> , sprinklers may be used in the <i>mercantile occupancy</i> or <i>medium hazard industrial occupancy</i> , with a 1 h <i>fire separation</i> .
152.	C152	9.10.9.14.(1) and (3); 9.10.9.15.(1)	(a) Except as provided in (b) and (c), 30 min <i>fire separation</i> is acceptable. (b) In a <i>house</i> , 15 min horizontal <i>fire separation</i> is acceptable where, (i) <i>smoke alarms</i> are installed in every <i>dwelling unit</i> and in common areas in conformance with Subsection 9.10.19., and (ii) <i>smoke alarms</i> are interconnected. (c) In a <i>house</i> , the <i>fire-resistance rating</i> of the <i>fire separation</i> is waived where the <i>building</i> is <i>sprinklered</i> .
153.	C153	9.10.10.3.	(a) Except as provided in (b) and (c) and in Articles 9.10.10.5. and 9.10.10.6., 30 min <i>fire separation</i> is acceptable. (b) In a <i>house</i> , the <i>fire-resistance rating</i> of the vertical <i>fire separation</i> is waived where, (i) <i>smoke alarms</i> are installed in every <i>dwelling unit</i> and in common areas in conformance with Subsection 9.10.19., and (ii) <i>smoke alarms</i> are interconnected. (c) In a <i>house</i> , the <i>fire-resistance rating</i> of the vertical <i>fire separation</i> is waived where <i>service rooms</i> are <i>sprinklered</i> .
154.	C154	9.10.11.2.(1)	In a <i>house</i> , a <i>party wall</i> with 1 h <i>fire-resistance rating</i> is acceptable.
155.	C155	9.10.13.1	Existing functional <i>closures</i> are acceptable subject to C.A.'s C8 and C156.
156.	C156	9.10.13.2.(1)	In a <i>house</i> , existing unlabelled doors at least 45 mm solid core wood or metal clad are acceptable. For existing <i>closures</i> , ratings of 20 min will not be required where the entire <i>floor area</i> is <i>sprinklered</i> .
157.	C157	9.10.13.2.(1)	In a <i>building</i> containing not more than

			four <i>dwelling units</i> or <i>suites</i> , existing glazed solid wood doors to corridors may remain in lieu of new 20 min doors, provided they are not located in a dead end corridor.
158.	C158	9.10.13.3.	Existing acceptable provided that wood door frames are secured with hinge screws going through frame into the stud.
159.	C159	9.10.13.5.	Existing wired glass acceptable.
			Existing transoms or sidelights located in required <i>fire separations</i> may be retained if wired glass, at least 6 mm thick, is securely fixed to a wood frame of at least 50 mm thickness with steel stops. Operable transoms shall be fixed closed.
160.	C160	9.10.13.6.	Existing steel door frames acceptable.
161.	C161	9.10.13.7.	Existing glass block acceptable.
162.	C162	9.10.13.8.	Existing sizes acceptable.
163.	C163	9.10.13.9.	Existing operable latches acceptable.
164.	C164	9.10.13.10.(1)	Existing functionally operable self-closing devices acceptable.
165.	C165	9.10.13.11.	Existing operable self-releasing electromagnetic hold-open device acceptable, and except for <i>hotels</i> , fusible link hold-open devices acceptable.
166.	C166	9.10.13.12.	Existing swings acceptable.
167.	C167	9.10.13.13.(1)	Except as permitted in C.A.C168, in a <i>building</i> containing not more than four <i>dwelling units</i> , the existing heating or <i>air-conditioning</i> system may be altered to serve more than one <i>dwelling unit</i> , provided <i>smoke alarms</i> are installed in each <i>dwelling unit</i> and provided a <i>smoke detector</i> is installed in the supply or return air duct system serving the entire <i>building</i> which would turn off the fuel supply and electrical power to the heating system upon activation of such detector.
168.	C168	9.10.13.13.(1)	In a <i>house</i> , existing acceptable.
169.	C169	9.10.13.14.; 9.10.5.1.	Except as permitted in C.A.C170, in a <i>building</i> containing not more than four <i>dwelling units</i> , the existing heating or <i>air-conditioning</i> system may be altered to serve more than one <i>dwelling unit</i> , provided <i>smoke alarms</i> are installed in each <i>dwelling unit</i> and provided a <i>smoke</i>

			<i>detector</i> is installed in the supply or return air duct system serving the entire <i>building</i> which would turn off the fuel supply and electrical power to the heating system upon activation of such detector.
170.	C170	9.10.13.14.; 9.10.5.1.	In a <i>house</i> , existing acceptable.
171.	C171	9.10.14.2.(2) and (3); 9.10.14.4.(2); 9.10.15.2.(2) and (3); 9.10.15.4.(4)	Where an addition to an existing residential <i>building</i> has its <i>exposing building face</i> further distant from the line than the existing <i>exposing building face</i> and the <i>limiting distance</i> is at least 1 200 mm, the total area of allowable <i>unprotected openings</i> may be determined under Sentence 9.10.14.2.(2) or 9.10.15.2.(2) for the combined new and existing <i>exposing building faces</i> and,
			(a) where the existing <i>exposing building face</i> has no <i>unprotected openings</i> , or the existing <i>unprotected openings</i> are to be filled in, the total allowable area of <i>unprotected openings</i> may be installed in the new <i>exposing building face</i> , or
			(b) where the existing <i>unprotected openings</i> are to remain,
			(i) their area shall be deducted from the total allowable area of <i>unprotected openings</i> , and the balance may be installed in the new <i>exposing building face</i> , and
			(ii) Sentences 9.10.14.2.(3) and 9.10.14.4.(2) or Sentences 9.10.15.2.(3) and 9.10.15.4.(4) apply only to the new <i>exposing building face</i> .
172.	C172	9.10.14.4.; 9.10.15.4.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies no closer than 300 mm from a window in such other <i>building</i> , where the “opposite”

			window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, to be restricted to the same <i>fire compartment</i> and shall conform to the requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
173.	C173	9.10.16.2.(1)	Where balloon framing is exposed during renovation, <i>fire blocks</i> shall be provided.
174.	C174	9.10.18.	(a) Subject to approval by the <i>chief building official</i> , existing fire alarm system may remain where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as required, Fire Department connection, and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
175.	C175	9.10.19.4.	<i>Smoke alarms</i> may be battery operated.
176.	C176	9.10.20.	Existing access acceptable.
177.	C177	9.14.2.1.(2)	Existing acceptable.
178.	C178	9.18.2.	Existing access acceptable.
179.	C179	9.18.3.	Existing vents and ventilation acceptable.
180.	C180	9.19.	Existing acceptable.
181.	C181	9.20.2.2.	Used masonry may be reused for patching and filling openings to match adjacent work. Used interior brick may not be used for exterior applications.
182.	C182	9.20.3.	Archaic mortars may be used to match existing jointing.



183.	C183	9.20.4.1.	Sound jointing techniques may be employed to match existing archaic joints.
184.	C184	9.20.12.1.	Corbelling may be constructed to match existing or original details, provided that it is structurally adequate for the proposed use.
185.	C185	9.21.	Existing acceptable, provided the products of combustion are safely vented and provided no fire hazard is created.
186.	C186	9.22.1. to 9.22.7.	Sound period materials, designs and techniques may be employed in recreated fireplaces, provided no fire hazard is created. Existing need not comply with Article 9.22.1.4.
187.	C187	9.23.	Existing acceptable.
188.	C188	9.24.	Existing acceptable.
189.	C189	9.25.	A <i>vapour barrier</i> may consist of paint or other coating with specified perm rating such as two coats of leafing aluminum pigmented paint.
190.	C190	9.26.	Existing acceptable, except when removing and replacing shingles, comply with the eave protection requirements of Subsection 9.26.5.
191.	C191	9.27.	Existing acceptable.
192.	C192	9.28.	All replacement or recreation of existing stucco may be compatible with the existing materials and application.
193.	C193	9.29.4.	Existing acceptable. All replacement or recreation of existing plaster may be compatible with the existing materials and application.
194.	C194	9.32.	In a <i>house</i> , rooms or spaces to be ventilated by natural means in accordance with Subsection 9.32.2. or by providing adequate mechanical ventilation.
195.	C195	9.33.1.1.	In a <i>building</i> containing not more than four <i>dwelling units</i> , the existing heating or <i>air-conditioning</i> system may be altered to serve more than one <i>dwelling unit</i> , provided <i>smoke alarms</i> are installed in each <i>dwelling unit</i> and provided a <i>smoke detector</i> is installed in the supply or return air duct system serving the entire <i>building</i> which would turn off the fuel

			supply and electrical power to the heating system upon activation of such detector.
196.	C196	9.33.1.2.	Sound, used or antique <i>appliances</i> are acceptable, provided that:
			(a) visual examination shows no excessive weakening by corrosion or other damage,
			(b) no structural parts are missing,
			(c) no cracks are present in the components intended to support the <i>appliance</i> or enclose the fire, and
			(d) loading and ash removal door latches and hinges hold the door closed.
197.	C197	9.33.4.3.(1)	Carbon monoxide alarms may be battery operated or plugged into an electrical outlet.
198.	C198	9.37.	Sound used materials shall be acceptable for reuse, subject to the following limitations:
			(a) visual examination shows no excessive weakening by holes, notches, nail splits or other damage, and
			(b) logs have not been subjected to termite infestation.
	<b>NUMBER</b>	<b>PART 12 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
199.	C199	12.2.1.1.(3)	(a) Where the framing systems are being altered to match the existing framing, lesser amounts and extent of insulation and <i>vapour barrier</i> is acceptable.
			(b) Existing acceptable for Article 2.1.1.9. of MMA Supplementary Standard SB-12, "Energy Efficiency for Housing".
			(c) Existing previously occupied log houses that are dismantled and reconstructed are exempt from Article 2.1.1.5. of MMA Supplementary Standard SB-12, "Energy Efficiency for Housing".

Table 11.5.1.1.D/E.

## Compliance Alternatives for Business/Mercantile Occupancies

Forming Part of Article 11.5.1.1.

Item	Col. 1 <b>NUMBER</b>	Column 2 <b>PART 3 REQUIREMENTS</b>	Column 3 <b>PART 11 COMPLIANCE ALTERNATIVE</b>

1.	DE1	3.1.4.7.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of member sizes listed in Part 3.
2.	DE2	3.1.5.2. to 3.1.5.4.; 3.1.5.6.	Existing acceptable.
3.	DE3	3.1.5.7. to 3.1.5.10.	Except for exposed foamed plastics, existing acceptable. To match existing, materials may be added from on or off site.
4.	DE4	3.1.5.15. to 3.1.5.17.; 3.1.5.21.; 3.1.4.23.	Existing acceptable.
5.	DE5	3.1.7.1.	<i>Fire-resistance ratings</i> may also be used where they are based on:
			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".
			3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".
			4. DBR Technical Paper No. 222, "Fire Endurance of Light-Framed and Miscellaneous Assemblies".
6.	DE6	3.1.7.5.(3)	Existing assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
7.	DE7	3.1.8.1.(2); 3.1.8.6.	Existing functional <i>closures</i> are acceptable and may be relocated within the same existing <i>fire separation</i> .
8.	DE8	3.1.8.5.(2)	(a) Existing functional and sound doors in existing <i>buildings</i> that are either hollow metal or kalamein and containing wired glass at least 6 mm thick and conforming to Sentence 3.1.8.14.(2) are permitted in lieu of doors not required to exceed 45 min,
			(b) all existing functional and sound hollow doors which carry existing 1.5 h labels are acceptable in lieu of current 1.5 h labels and may contain wired glass panels not

			exceeding 0.0645 m <sup>2</sup> , at least 6 mm thick and conforming to Sentence 3.1.8.14.(2), and
			(c) every fire door, window assembly or glass block used as a <i>closure</i> in a required <i>fire separation</i> shall be installed in conformance with good engineering practice.
9.	DE9	3.1.8.7.; 3.1.8.9.	<i>Fire dampers</i> or <i>fire stop flaps</i> are not required to be installed in existing ducts at penetrations of existing <i>fire separations</i> .
10.	DE10	3.1.8.10.(1)	For existing unlabelled doors in existing <i>buildings</i> , at least 45 mm solid core wood or metal clad are acceptable.
11.	DE11	3.1.8.13.	Existing functionally operable latching devices, excluding draw bolts, are acceptable.
12.	DE12	3.1.8.14.	Existing transoms or sidelights located in required <i>fire separations</i> may be retained if wired glass, at least 6 mm thick, is securely fixed to a wood frame of at least 50 mm thickness with steel stops. Operable transoms shall be fixed closed.
13.	DE13	3.1.8.15. to 3.1.8.17.	Existing acceptable.
14.	DE14	3.1.11.	Where the concealed space is being materially altered, smoke or heat detection in that space in lieu of <i>fire blocks</i> and tied into fire alarm system is acceptable.
15.	DE15	3.2.2.17.(1)(b) and (c)	Existing sprinkler systems in 1 <i>storey buildings</i> need not comply.
16.	DE16	3.2.3.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies not closer than 300 mm from a window in such other <i>building</i> , where the “opposite” window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, shall be restricted to the same <i>fire compartment</i> and shall conform to the

			requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
17.	DE17	3.2.3.6.(3)	Existing roof soffit projections acceptable.
18.	DE18	3.2.3.17.	Need not comply for “E” <i>occupancy</i> .
19.	DE19	3.2.4.	(a) Existing fire alarm system may remain except that Article 3.2.4.5. does not apply where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as required, Fire Department connection, and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
20.	DE20	3.2.4.9.(2)(e)	Does not apply to existing installations in <i>buildings</i> .
21.	DE21	3.2.4.10.(5)(c)	Does not apply to existing installations in <i>buildings</i> .
22.	DE22	3.2.5.1.; 3.2.5.2.	Existing acceptable.
23.	DE23	3.2.5.3.	Existing access acceptable.
24.	DE24	3.2.5.4. to 3.2.5.6.	Existing acceptable provided the <i>building</i> is <i>sprinklered</i> .
25.	DE25	3.2.5.7.	Does not apply, except where a change in <i>major occupancy</i> occurs from a lesser <i>hazard index</i> .
26.	DE26	3.2.5.13.	Existing sprinkler systems in existing <i>buildings</i> that do not conform to NFPA 13 may be altered, added to, or extended from the existing system without complying with NFPA 13, provided the

			system is operational and adequate with respect to coverage, water supply and controls, and provided the system is evaluated by a qualified designer.
27.	DE27	3.2.9.	Does not apply to <i>buildings 6 storeys and less</i> .
			Does not apply to <i>sprinklered buildings</i> .
28.	DE28	3.3.1.5.(1)(c); Tables 3.3.1.5.A. and 3.3.1.5.B.	In Column 2, maximum area of room or <i>suite</i> to be unlimited.
29.	DE29	3.3.1.9.(1)	Existing width of <i>public corridors</i> of not less than 914 mm is acceptable.
30.	DE30	3.3.1.10.; 3.3.1.11.	Existing door swings may remain in <i>heritage buildings</i> , existing or being restored, with no change in <i>major occupancy</i> and with <i>occupant load</i> no greater than 100.
31.	DE31	3.3.1.12.	Existing doors acceptable, provided not less than 600 mm wide.
32.	DE32	3.3.1.15.	Existing curved or spiral stairs acceptable.
33.	DE33	3.3.1.16.	Existing non-conforming capacities of <i>access to exits</i> are acceptable, provided that:
			(a) the increase in <i>occupant load</i> is not greater than 15%,
			(b) the corridor <i>fire separations</i> are rated to Code, and
			(c) early warning systems are provided, or
			(d) there are sprinklers, plus <i>smoke alarms</i> in <i>suites</i> .
34.	DE34	3.3.1.17.	Does not apply to <i>heritage buildings</i> .
35.	DE35	3.3.1.18.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
36.	DE36	3.3.5.4.; 3.3.5.7. (3)	Need not comply where a gasketed door and self closer are provided in the existing <i>fire separation</i> .
37.	DE37	3.4.1.4.	The following types of <i>exits</i> may also be used for <i>buildings</i> not over 6 <i>storeys</i> in <i>building height</i> :
			(a) connected balconies, which connect across <i>firewalls</i> , or connect to another <i>exit</i> , or with access to grade,
			(b) areas of refuge where fire service rescue is possible and that comply with Measure L of Sentences (4) to (10), (18),

			and Clauses (20)(a), (b) and (d) in MMAH Supplementary Standard SB-4, "Measures for Fire Safety in High Buildings".
38.	DE38	3.4.1.8.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
39.	DE39	3.4.2.5.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> .
40.	DE40	3.4.3.2.(7)	Existing width of <i>exits</i> acceptable provided the <i>occupant load</i> is not more than 15% above the <i>exit</i> capacity.
41.	DE41	3.4.3.4.	Existing acceptable.
42.	DE42	3.4.3.5.	Existing headroom clearance of not less than 1 980 mm is acceptable.
43.	DE43	3.4.4.1.	<i>Fire separations</i> of <i>exits</i> permitted in <i>buildings</i> :
			- 30 min, up to 3 <i>storeys</i> in <i>building height</i> ;
			- 45 min, up to 6 <i>storeys</i> in <i>building height</i> ;
			- 1 h, over 6 <i>storeys</i> in <i>building height</i> .
44.	DE44	3.4.4.4.(8)	Existing washrooms opening directly into <i>exit</i> stairwell shall be separated from <i>exit</i> stairwell by a 45 min <i>closure</i> .
45.	DE45	3.4.5.1.(2) and (9)	Existing illuminated legible <i>exit</i> signs are acceptable.
46.	DE46	3.4.6.1.	Existing acceptable.
47.	DE47	3.4.6.2.	Existing acceptable, if visually apparent.
48.	DE48	3.4.6.3.(1)	Existing acceptable with rise no greater than 3.7 m.
49.	DE49	3.4.6.4.(1)	Existing acceptable.
50.	DE50	3.4.6.4.(2) and (3)	Existing acceptable.
51.	DE51	3.4.6.5.(2) to (11)	Existing acceptable.
52.	DE52	3.4.6.6.(1) to (5)	Existing acceptable.
53.	DE53	3.4.6.7.(1)	Existing acceptable.
54.	DE54	3.4.6.8.	Existing acceptable.
55.	DE55	3.4.6.9.	Existing acceptable.
56.	DE56	3.4.6.10.(2) to (6)	Existing acceptable.
57.	DE57	3.4.6.11.(1) and (2)	Existing acceptable.
58.	DE58	3.4.6.12.	Existing acceptable in <i>public heritage buildings</i> or a change in <i>occupancy</i> with no increase in <i>occupant load</i> .
59.	DE59	3.4.6.13.	Existing acceptable.

60.	DE60	3.4.6.14.	Existing acceptable.
61.	DE61	3.4.6.16.	Existing functionally operable panic hardware acceptable.
62.	DE62	3.4.7.2.	<i>Combustible</i> fire escapes which are protected from fire in accordance with Sentence 3.2.3.13.(2) are permitted or may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
63.	DE63	3.5.1.	Existing acceptable except where <i>building</i> is classified under Subsection 3.2.6.
64.	DE64	3.6.2.1.(7)	Existing <i>fire separation</i> of not less than 30 min is acceptable
65.	DE65	3.6.2.2.	Existing acceptable where explosion-resistant <i>construction</i> or venting is provided.
66.	DE66	3.6.2.6.	Existing acceptable.
67.	DE67	3.6.2.7.(1)	2 h <i>fire separation</i> acceptable.
68.	DE68	3.6.3.1.(1) to (5)	45 min <i>fire separation</i> acceptable up to 6 <i>storeys</i> .
69.	DE69	3.6.3.3.	(a) Where 2 h <i>fire separation</i> is required, 1 h is acceptable.
			(b) Where 1 h <i>fire separation</i> is required, 45 min is acceptable.
			(c) Existing need not comply with Sentence 3.6.3.3.(5).
70.	DE70	3.6.4.2.	Ceiling <i>fire separation</i> need not have a <i>fire-resistance rating</i> where sprinklering, subject to C.A. DE27, of <i>fire compartments</i> on both sides of vertical <i>fire separation</i> is provided and where such <i>fire separation</i> is not required to exceed 1 h.
71.	DE71	3.6.4.3.(1)	Existing to meet <i>flame-spread rating</i> of 25 or to be <i>sprinklered</i> .
72.	DE72	3.6.4.4. to 3.6.4.6.	Existing access acceptable.
73.	DE73	3.7.4.	Where the <i>occupant load</i> is increased by more than 15% above the capacity of the existing facilities, facilities to be added to accommodate the increase.
74.	DE74	3.8.1.2.	Existing accessible entrance acceptable. (See C.A. DE78)
			Existing curb ramp conforming to Sentence 3.8.3.2.(3) is acceptable. Existing principal entrance acceptable,



			provided at least one <i>barrier-free</i> entrance is available.
75.	DE75	3.8.1.3.(1)	Existing unobstructed width of 920 mm minimum is acceptable.
76.	DE76	3.8.1.3.(4)	Existing unobstructed space not less than 1 500 mm in width and 1 500 mm in length located not more than 30 m apart is acceptable.
76.1	DE76.1	3.8.3.2.(3)(b)	Existing curb ramp acceptable, provided width not less than 1 200 mm.
77.	DE77	3.8.3.3.(1)	Existing doorway acceptable, provided not less than 810 mm wide.
77.1	DE77.1	3.8.3.3.(11)(a)	Existing distance acceptable, provided not less than 1 200 mm plus the width of any door that swings into the space in the path of travel.
78.	DE78	3.8.3.4.(1)(a)	Existing ramp acceptable, provided not less than 870 mm between handrails.
79.	DE79	3.8.3.8.(5)	Existing grab bar is acceptable.
79.1	DE79.1	3.8.3.12.	Existing universal washroom acceptable.
80.	DE80	3.8.3.13.(2)(f)	Existing grab bar is acceptable.
80.1	DE80.1	3.8.3.16.	Existing drinking fountain conforming to Clauses 3.8.3.16.(2)(a) and (b) acceptable.
	<b>NUMBER</b>	<b>PART 4 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
81.	DE81	4.1.8.	The requirements under this Subsection do not apply.
	<b>NUMBER</b>	<b>PART 6 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
82.	DE82	6.2.2.1.(2)	Required outdoor air rates may be provided by mechanical, natural or combination of natural and mechanical means.
83.	DE83	6.2.3.2.; 6.2.3.9.; 6.2.3.18; 6.2.3.19.	Existing acceptable.
84.	DE84	6.2.3.8.(18)	Existing acceptable.
85.	DE85	6.2.3.12.	Existing openings, grilles and diffusers acceptable, subject to approval of <i>chief building official</i> .
	<b>NUMBER</b>	<b>PART 8 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
86.	DE86	8.2.1.4.	Existing clearances acceptable where a <i>sewage system</i> is replaced with another <i>sewage system</i> within the same

			class and the capacity of the replacement <i>sewage system</i> does not exceed the capacity of the existing <i>sewage system</i> .
87.	DE87	8.2.1.4.	Existing clearances are acceptable where a replacement <i>sewage system</i> requires lesser clearances than those required in Part 8 for the existing <i>sewage system</i> .
	<b>NUMBER</b>	<b>PART 9 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
88.	DE88	9.3.2.1.	Sound used lumber may be acceptable for reuse without a grade stamp provided that:
			(a) visual examination shows no excessive weakening by holes, notches, nail splits or other damage,
			(b) where the grade or species is unknown, the minimum grade shall apply for span table use, and
			(c) lumber has not been subjected to termite infestation.
89.	DE89	9.5.11.2.	Existing acceptable, provided not less than 600 mm.
90.	DE90	9.6.1.2.(2) and (3); 9.6.1.4.(1) and (2)	Existing doors and sidelights being reused or relocated need not conform if identified or protected.
91.	DE91	9.6.1.4.(3) and (4); 9.8.8.1.(7) and (9)	Existing acceptable.
92.	DE92	9.7.	Existing acceptable.
93.	DE93	9.8.1. to 9.8.4.	Replacement or extension of existing stair systems shall be exempt from the provisions of these Subsections, except that they shall have:
			(a) a minimum width between wall faces of 700 mm, and
			(b) a minimum clear height over tread nosing or landing of 1 800 mm.
94.	DE94	9.8.3.2.	Existing acceptable.
95.	DE95	9.8.4.3.	Existing curved or spiral stairs acceptable.
96.	DE96	9.8.5.1.(2)	Existing ramps acceptable, where practical.
97.	DE97	9.8.7.	Existing handrails acceptable, unless considered unsafe by <i>chief building official</i> .

98.	DE98	9.8.8.	Existing <i>guards</i> acceptable, unless considered unsafe by <i>chief building official</i> .
99.	DE99	9.9.1.1.	Existing acceptable.
100.	DE100	9.9.2.1.(1) to (3)	The following types of <i>exits</i> may also be used:
			(a) connected balconies, which connect across <i>firewalls</i> , or connect to another <i>exit</i> , or with access to grade,
			(b) areas of refuge approved by the <i>chief building official</i> , where fire service rescue is possible, or
			(c) <i>combustible</i> or <i>noncombustible</i> exterior stairways or fire escapes which are protected in accordance with Sentence 3.2.3.13.(2). These may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
101.	DE101	9.9.2.1.(4)	Existing acceptable.
102.	DE102	9.9.3.2.	Existing width of <i>exits</i> acceptable.
103.	DE103	9.9.3.3.	Existing width of <i>public corridors</i> of not less than 965 mm is acceptable.
104.	DE104	9.9.3.4.	Existing clear height of not less than 1 950 mm is acceptable.
105.	DE105	9.9.4.2.	30 min <i>fire separation</i> acceptable.
106.	DE106	9.9.5.4.; 9.9.5.5.	Existing acceptable.
107.	DE107	9.9.5.8.	Existing acceptable provided minimum 45 min <i>fire separation</i> and where explosion-resistant <i>construction</i> or venting is provided.
108.	DE108	9.9.5.9.	Existing acceptable, provided that the enclosure has a 45 min <i>fire-resistance rating</i> .
109.	DE109	9.9.6.1.	Existing acceptable.
110.	DE110	9.9.6.2.	Existing clear opening height of not less than 1 950 mm is acceptable.
111.	DE111	9.9.6.3.	Existing door widths are acceptable, provided <i>exit</i> widths comply with C.A.DE103.
112.	DE112	9.9.6.5.	Existing door swings are acceptable.
			Existing acceptable in <i>public heritage buildings</i> , where approved by <i>chief building official</i> .
113.	DE113	9.9.6.6.(1)	Where <i>exit</i> doors open onto a landing, they shall not extend beyond the face of

			the first riser.
114.	DE114	9.9.6.8.	Existing functionally operable passage or panic hardware acceptable.
115.	DE115	9.9.7.4.	Maximum area of existing room or <i>suite</i> to be unlimited.
116.	DE116	9.9.8.2.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> and provided <i>fire separations</i> comply with Part 9.
117.	DE117	9.9.11.3.	Existing illuminated legible signs are acceptable for <i>exitsigns</i> , if approved by <i>chief building official</i> .
118.	DE118	9.10.1.1.	Assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
119.	DE119	9.10.1.3.(8) to (10)	Existing installations acceptable subject to C.A.'s DE26 and DE27.
120.	DE120	9.10.3.	<i>Fire-resistance ratings</i> may also be used where they are based on:
			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".
			3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".
			4. DBR Technical Paper No. 222, "Fire Endurance of Light-Framed and Miscellaneous Assemblies".
121.	DE121	9.10.5.1.	(a) Existing openings in existing wall or ceiling membranes to remain.
			(b) Existing openings may be moved to another location in the same wall or ceiling, provided the aggregate area of openings does not increase and are not cumulative, and the existing opening is blocked up to provide the same rating as the existing wall or ceiling assembly.
122.	DE122	9.10.6.2.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of the member sizes listed in Part 3.

123.	DE123	9.10.7.	Existing acceptable for <i>heritage buildings</i> , subject to approval of <i>chief building official</i> .
124.	DE124	9.10.8.1.	Existing 30 min rating acceptable.
125.	DE125	9.10.8.2.	Existing sprinkler systems complying with C.A. DE27 and Sentence 3.2.2.17.(1) are acceptable.
126.	DE126	9.10.8.3.	Existing acceptable, subject to approval of the <i>chief building official</i> .
127.	DE127	9.10.8.8.	30 min rating acceptable.
128.	DE128	9.10.9.7.; 9.10.9.9.	Existing acceptable in existing <i>fire separations</i> .
129.	DE129	9.10.9.10.(1)	Ceiling <i>fire separation</i> need not be fire-resistance rated where sprinklering of <i>fire compartments</i> on both sides of vertical <i>fire separation</i> is provided and where such <i>fire separation</i> is not required to exceed 1 h.
130.	DE130	9.10.9.11.(2)	In lieu of the 2 h <i>fire separation</i> , sprinklers may be used in the <i>mercantile occupancy</i> with a 1 h <i>fire separation</i> .
131.	DE131	9.10.9.13.	30 min <i>fire separation</i> acceptable.
132.	DE132	9.10.9.15.(1)	30 min <i>fire separation</i> acceptable.
133.	DE133	9.10.9.15.(3)	Need not comply for <i>mercantile occupancy</i> .
134.	DE134	9.10.10.3.(1)	45 min <i>fire separation</i> acceptable.
135.	DE135	9.10.13.1.	Existing functional <i>closures</i> are acceptable subject to C.A.DE8.
136.	DE136	9.10.13.2.	Existing acceptable.
137.	DE137	9.10.13.3.	Existing acceptable, provided that wood door frames are secured with hinge screws going through frame into the stud.
138.	DE138	9.10.13.5.	Existing acceptable.
			Existing transoms or sidelights located in required <i>fire separations</i> may be retained if wired glass, at least 6 mm thick, is securely fixed to a wood frame of at least 50 mm thickness with steel stops. Operable transoms shall be fixed closed.
139.	DE139	9.10.13.6.	Existing steel door frames acceptable.
140.	DE140	9.10.13.7.	Existing glass block acceptable.
141.	DE141	9.10.13.8.	Existing sizes acceptable.
142.	DE142	9.10.13.9.	Existing operable latches acceptable.
143.	DE143	9.10.13.10.(1)	Existing functionally operable self-closing devices acceptable.

144.	DE144	9.10.13.10.(2)	Existing functionally operable self-closing devices acceptable in “E” <i>occupancy</i> .
145.	DE145	9.10.13.11.	Existing operable self-releasing electromagnetic and fusible link hold-open devices acceptable.
146.	DE146	9.10.13.12.	Existing swings acceptable.
147.	DE147	9.10.14.4.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies no closer than 300 mm from a window in such other <i>building</i> , where the “opposite” window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, to be restricted to the same <i>fire compartment</i> and shall conform to the requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
148.	DE148	9.10.16.2.(1)	Where balloon framing is exposed during renovation, <i>fire blocks</i> shall be provided.
149.	DE149	9.10.18.	(a) Subject to approval by the <i>chief building official</i> , existing fire alarm system may remain where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of 3.2.4. (i.e. “stage” system, electrical supervision, detection as required, Fire

			Department connection, and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
150.	DE150	9.10.20.	Existing access acceptable.
151.	DE151	9.18.2.	Existing access acceptable.
152.	DE152	9.18.3.	Existing vents and ventilation acceptable.
153.	DE153	9.19.	Existing acceptable.
154.	DE154	9.20.2.2.	Used masonry may be reused for patching and filling openings to match adjacent work. Used interior brick may not be used for exterior applications.
155.	DE155	9.20.3.	Archaic mortars may be used to match existing jointing.
156.	DE156	9.20.4.1.	Sound jointing techniques may be employed to match existing archaic joints.
157.	DE157	9.20.12.1.	Corbelling may be constructed to match existing or original details, provided that it is structurally adequate for the proposed use.
158.	DE158	9.21.	Existing acceptable, provided the products of combustion are safely vented and provided no fire hazard is created.
159.	DE159	9.22.1. to 9.22.7.	Sound period materials, designs and techniques may be employed in recreated fireplaces, provided no fire hazard is created.
			Existing need not comply with Article 9.22.1.4.
160.	DE160	9.23.	Existing acceptable.
161.	DE161	9.24.	Existing acceptable.
162.	DE162	9.26.	Existing acceptable, except when removing and replacing shingles, comply with eave protection requirements in Subsection 9.26.5.
163.	DE163	9.27.	Existing acceptable.
164.	DE164	9.28.	All replacement or recreation of existing stucco may be compatible with the existing materials and application.
165.	DE165	9.29.4.	Existing acceptable. All replacement or recreation of existing plaster may be compatible with the existing materials and application.
166.	DE166	9.33.1.2.	Sound, used or antique <i>appliances</i> are

			acceptable, provided that:
			(a) visual examination shows no excessive weakening by corrosion or other damage,
			(b) no structural parts are missing,
			(c) no cracks are present in the components intended to support the <i>appliance</i> or enclose the fire, and
			(d) loading and ash removal door latches and hinges hold the door closed.
167.	DE167	9.37.	Sound used materials shall be acceptable for reuse, subject to the following limitations:
			(a) visual examination shows no excessive weakening by holes, notches, nail splits or other damage, and
			(b) logs have not been subjected to termite infestation.

**Table 11.5.1.1.F.**  
**Compliance Alternatives for Industrial Occupancies**

Forming Part of Article 11.5.1.1.

Item	Col. 1 NUMBER	Column 2 <b>PART 3 REQUIREMENTS</b>	Column 3 <b>PART 11 COMPLIANCE ALTERNATIVE</b>
1.	F1	3.1.4.7.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of member sizes listed in Part 3.
2.	F2	3.1.5.2. to 3.1.5.4.; 3.1.5.6.	Existing acceptable.
3.	F3	3.1.5.7. to 3.1.5.10.	Except for exposed foamed plastics, existing acceptable for "F2" and "F3" <i>occupancies</i> . To match existing, materials may be added from on or off site.
4.	F4	3.1.5.15. to 3.1.5.17.; 3.1.5.21.; 3.1.5.23.	Existing acceptable.
5.	F5	3.1.7.1.	<i>Fire-resistance ratings</i> may also be used where they are based on:
			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and



			Beams”.
			3. DBR Technical Paper No. 207, “Fire Endurance of Unit Masonry Walls”.
			4. DBR Technical Paper No. 222, “Fire Endurance of Light-Framed and Miscellaneous Assemblies”.
6.	F6	3.1.7.5.(3)	Existing assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
7.	F7	3.1.8.1.(2); 3.1.8.6.	Existing functional <i>closures</i> are acceptable and may be relocated within the same existing <i>fire separation</i> .
8.	F8	3.1.8.5.(2)	(a) Existing functional and sound doors in existing <i>buildings</i> that are either hollow metal or kalamein and containing wired glass at least 6 mm thick and conforming to Sentence 3.1.8.14.(2) are permitted in lieu of doors not required to exceed 45 min,
			(b) all existing functional and sound hollow metal or kalamein doors which carry existing 1.5 h labels are acceptable in lieu of current 1.5 h labels and may contain wired glass panels not exceeding 0.0645 m <sup>2</sup> , at least 6 mm thick and conforming to Sentence 3.1.8.14.(2), and
			(c) every fire door, window assembly or glass block used as a <i>closure</i> in a required <i>fire separation</i> shall be installed in conformance with good engineering practice.
9.	F9	3.1.8.7.; 3.1.8.9.	<i>Fire dampers</i> or <i>fire stop flaps</i> are not required to be installed in existing ducts at penetrations of existing <i>fire separations</i> .
10.	F10	3.1.8.10.(1)	For existing unlabelled doors in existing <i>buildings</i> , at least 45 mm solid core wood or metal clad are acceptable.
11.	F11	3.1.8.11.(1)	Existing functionally operable devices acceptable for “F2” and “F3” <i>occupancies</i> .
12.	F12	3.1.8.13.	Existing functionally operable latching devices, excluding draw bolts, are acceptable.
13.	F13	3.1.8.14.	Existing transoms or sidelights located in required <i>fire separations</i> may be retained if wired glass, at least 6 mm thick, is securely fixed to a wood frame of at least 50 mm thickness with steel stops. Operable transoms shall be fixed closed.

14.	F14	3.1.8.15. to 3.1.8.17.	Existing acceptable.
15.	F15	3.1.11.	Where the concealed space is being materially altered, smoke or heat detection in that space in lieu of <i>fire blocks</i> and tied into fire alarm system is acceptable.
16.	F16	3.2.2.17.(1)(b) and (c)	Existing sprinkler systems in 1 <i>storey buildings</i> need not comply.
17.	F17	3.2.3.	Existing need not comply with Article 3.2.3.18. for “F2” <i>occupancy</i> .
			Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies not closer than 300 mm from a window in such other <i>building</i> , where the “opposite” window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, shall be restricted to the same <i>fire compartment</i> and shall conform to the requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
18.	F18	3.2.3.6.(3)	Existing roof soffit projections acceptable.
19.	F19	3.2.3.17.	Need not comply for “F2” <i>occupancy</i> .
20.	F20	3.2.4.	(a) Existing fire alarm system may remain except that Article 3.2.4.5. does not apply where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as

			required, Fire Department connection, and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
21.	F21	3.2.4.9.(2)(e)	Does not apply to existing installations in <i>buildings</i> .
22.	F22	3.2.4.10.(5)(c)	Does not apply to existing installations in <i>buildings</i> .
23.	F23	3.2.5.1; 3.2.5.2.	Existing acceptable.
24.	F24	3.2.5.3.	Existing access acceptable.
25.	F25	3.2.5.4. to 3.2.5.6.	Existing acceptable provided the <i>building</i> is <i>sprinklered</i> .
26.	F26	3.2.5.7.	Does not apply, except where a change in <i>major occupancy</i> occurs from a lesser <i>hazard index</i> .
27.	F27	3.2.5.13.	Existing sprinkler systems in existing <i>buildings</i> that do not conform to NFPA 13 may be altered, added to, or extended from the existing system without complying with NFPA 13, provided the system is operational and adequate with respect to coverage, water supply and controls, and provided the system is evaluated by a qualified designer.
28.	F28	3.2.9.	Does not apply to <i>buildings</i> 6 storeys and less of "F2" and "F3" <i>occupancies</i> . Does not apply to <i>sprinklered buildings</i> .
29.	F29	3.3.1.4.(1)	30 min is acceptable to separate <i>public corridors</i> or <i>exits</i> in <i>buildings</i> not exceeding 6 storeys in <i>building height</i> , except that 45 min is required for <i>exits</i> in <i>buildings</i> exceeding 3 storeys in <i>building height</i> .
			Except for <i>exits</i> , no rating required where <i>floor areas</i> are <i>sprinklered</i> .
30.	F30	3.3.1.5.(1)(c); Tables 3.3.1.5.A. and 3.3.1.5.B.	For "F2" and "F3" <i>occupancies</i> in Column 2, maximum area of room or <i>suite</i> to be unlimited.
31.	F31	3.3.1.9.	Existing width of <i>public corridors</i> of not less than 914 mm is acceptable.
32.	F32	3.3.1.9.(13) and (14)	Need not comply where connected balcony or area of refuge is provided in compliance with C.A. F39.
33.	F33	3.3.1.10.; 3.3.1.11.	Existing door swings may remain in <i>heritage buildings</i> , existing or being restored, with no

			change in <i>major occupancy</i> and with <i>occupant load</i> no greater than 100.
34.	F34	3.3.1.12.	Existing doors acceptable, provided not less than 600 mm wide.
35.	F35	3.3.1.15.	Existing curved or spiral stairs acceptable.
36.	F36	3.3.1.18.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
37.	F37	3.3.5.4.(2), (3) and (5)	Existing acceptable.
38.	F38	3.3.5.6.; 3.3.5.7.	Need not comply where a gasketed door and self closer are provided in the existing <i>fire separation</i> .
39.	F39	3.4.1.4.	For “F2” and “F3” <i>occupancies</i> , the following types of <i>exits</i> may also be used for <i>buildings</i> not over 6 <i>storeys</i> in <i>building height</i> :
			(a) connected balconies, which connect across <i>firewalls</i> , or connect to another <i>exit</i> , or with access to grade,
			(b) areas of refuge where fire service rescue is possible and that comply with Measure L in Sentences (4) to (10), (18) and Clauses (20)(a), (b) and (d) in MMAH Supplementary Standard SB-4, “Measures for Fire Safety in High Buildings”.
40.	F40	3.4.1.8.	Existing stained, etched, bevelled, leaded or figured glass acceptable.
41.	F41	3.4.2.5.(1)	For “F2” and “F3” <i>occupancies</i> , existing travel distance acceptable where the <i>floor areas</i> <i>sprinklered</i> .
42.	F42	3.4.3.2.(7)	For “F2” and “F3” <i>occupancies</i> , existing width of <i>exits</i> acceptable provided the <i>occupant load</i> is not more than 15% above the <i>exit</i> capacity.
43.	F43	3.4.3.4.	Existing acceptable.
44.	F44	3.4.3.5.	Existing headroom clearance of not less than 1 980 mm is acceptable.
45.	F45	3.4.4.1.	<i>Fire separations</i> of <i>exits</i> permitted in <i>buildings</i> :
			- 30 min, up to 3 <i>storeys</i> in <i>building height</i> ;
			- 45 min, up to 6 <i>storeys</i> in <i>building height</i> ;
			- 1 h, over 6 <i>storeys</i> in <i>building height</i> .
46.	F46	3.4.4.4.(8)	Existing washrooms opening directly into <i>exit</i> stairwell shall be separated from <i>exit</i> stairwell by 45 min <i>closure</i> .
47.	F47	3.4.5.1.(2) and (9)	Existing illuminated legible <i>exit</i> signs are acceptable.
48.	F48	3.4.6.1.	Existing acceptable.

49.	F49	3.4.6.2.	Existing acceptable, if visually apparent.
50.	F50	3.4.6.3.(1)	Existing acceptable with rise no greater than 3.7 m.
51.	F51	3.4.6.4.(1)	Existing acceptable.
52.	F52	3.4.6.4.(2) and (3)	Existing acceptable.
53.	F53	3.4.6.5.(2) to (11)	Existing acceptable.
54.	F54	3.4.6.6.(1) to (5)	Existing acceptable.
55.	F55	3.4.6.7.(1)	Existing acceptable.
56.	F56	3.4.6.8.	Existing acceptable.
57.	F57	3.4.6.9.	Existing acceptable.
58.	F58	3.4.6.10.(2) to (6)	Existing acceptable.
59.	F59	3.4.6.11.(1) and (2)	Existing acceptable.
60.	F60	3.4.6.12.	For “F2” and “F3” <i>occupancies</i> , existing acceptable in <i>public heritage buildings</i> or a change in <i>occupancy</i> with no increase in <i>occupant load</i> .
61.	F61	3.4.6.13.; 3.4.6.14.	Existing acceptable.
62.	F62	3.4.6.16.	Existing functionally operable panic hardware acceptable.
63.	F63	3.4.7.2.	<i>Combustible</i> fire escapes which are protected from fire in accordance with Sentence 3.2.3.13. (2) are permitted or may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
64.	F64	3.5.1.	Existing acceptable, except where <i>building</i> classified under Subsection 3.2.6. and except where existing elevators are “open” type.
65.	F65	3.6.2.1.(7)	45 min <i>fire separation</i> acceptable.
66.	F66	3.6.2.2.	Existing acceptable where explosion-resistant <i>construction</i> or venting is provided.
67.	F67	3.6.2.6.	Existing acceptable.
68.	F68	3.6.2.7.(1)	2 h <i>fire separation</i> acceptable.
69.	F69	3.6.3.1.(1) to (5)	45 min <i>fire separation</i> acceptable up to 6 <i>storeys</i> .
70.	F70	3.6.3.3.	(a) Where 2 h <i>fire separation</i> is required, 1 h is acceptable.  (b) Where 1 h <i>fire separation</i> is required, 45 min is acceptable.  (c) Existing need not comply with Sentences 3.6.3.3.(4) and (5).
71.	F71	3.6.4.2.	Ceiling <i>fire separation</i> need not be fire-resistance rated where sprinklering, subject

			to C.A.F27, of <i>fire compartments</i> on both sides of vertical <i>fire separation</i> is provided and where such <i>fire separation</i> is not required to exceed 1 h.
72.	F72	3.6.4.3.(1)	Existing to meet <i>flame-spread rating</i> of 25 or to be <i>sprinklered</i> .
73.	F73	3.6.4.4. to 3.6.4.6.	Existing access acceptable.
74.	F74	3.7.4.	Where the <i>occupant load</i> is increased by more than 15% above the capacity of the existing facilities, facilities to be added to accommodate the increase.
75.	F75	3.8.1.2.	Existing accessible entrance acceptable. (See C.A. F79)
			Existing curb ramp conforming to Sentence 3.8.3.2.(3) is acceptable. Existing principal entrance acceptable, provided at least one <i>barrier-free</i> entrance is available.
76.	F76	3.8.1.3.(1)	Existing unobstructed width of 920 mm minimum is acceptable.
77.	F77	3.8.1.3.(4)	Existing unobstructed space not less than 1 500 mm in width and 1 500 mm in length located not more than 30 m apart is acceptable.
77.1	F77.1	3.8.3.2.(3)(b)	Existing curb ramp acceptable, provided width not less than 1 200 mm.
78	F78	3.8.3.3.(1)	Existing doorway acceptable, provided not less than 810 mm wide.
78.1	F78.1	3.8.3.3.(11)(a)	Existing distance acceptable, provided not less than 1 200 mm plus the width of any door that swings into the space in the path of travel.
79.	F79	3.8.3.4.(1)(a)	Existing ramp acceptable, provided not less than 870 mm between handrails.
80.	F80	3.8.3.8.(5)	Existing grab bar is acceptable.
80.1	F80.1	3.8.3.12.	Existing universal washroom acceptable.
81.	F81	3.8.3.13.(2)(f)	Existing grab bar is acceptable.
81.1	F81.1	3.8.3.16.	Existing drinking fountain conforming to Clauses 3.8.3.16.(2)(a) and (b) acceptable.
	<b>NUMBER</b>	<b>PART 4 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
82.	F82	4.1.8.	The requirements under this Subsection do not apply.
	<b>NUMBER</b>	<b>PART 6 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
83.	F83	6.2.2.3.(1), (3) and (4)	<i>Storage garages</i> with a total capacity of fewer than 20 motor vehicles need not have mechanical ventilating systems if the downward

			slope of the floor to the outside door is 1 in 120 and the garage floor is above outside ground level.
84.	F84	6.2.3.2.; 6.2.3.9.; 6.2.3.18; 6.2.3.19.	Existing acceptable for "F2" and "F3" <i>occupancies</i> .
85.	F85	6.2.3.12.	Existing openings, grilles and diffusers acceptable.
86.	F86	6.2.9.2.	Existing acceptable for "F2" and "F3" <i>occupancies</i> .
	<b>NUMBER</b>	<b>PART 8 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
87.	F87	8.2.1.4.	Existing clearances acceptable where a <i>sewage system</i> is replaced with another <i>sewage system</i> within the same class and the capacity of the replacement <i>sewage system</i> does not exceed the capacity of the existing <i>sewage system</i> .
88.	F88	8.2.1.4.	Existing clearances are acceptable where a replacement <i>sewage system</i> requires lesser clearances than those required in Part 8 for the existing <i>sewage system</i> .
	<b>NUMBER</b>	<b>PART 9 REQUIREMENTS</b>	<b>PART 11 COMPLIANCE ALTERNATIVE</b>
89.	F89	9.3.2.1.	Sound used lumber is acceptable for reuse without a grade stamp provided that:
			(a) visual examination shows no excessive weakening by holes, notches, nail splits or other damage,
			(b) where the grade or species is unknown, the minimum grade shall apply for span table use, and
			(c) lumber has not been subjected to termite infestation.
90.	F90	9.5.11.2.	Existing acceptable, provided not less than 600 mm.
91.	F91	9.6.1.2.(2) and (3); 9.6.1.4.(1) and (2)	Existing doors and sidelights being reused or relocated need not conform if identified or protected.
92.	F92	9.6.1.4.(3) and (4); 9.8.8.1.(7) and (9)	Existing barriers acceptable.
93.	F93	9.7.	Existing acceptable.
94.	F94	9.8.1. to 9.8.4.	Replacement or extension of existing stair systems shall be exempt from the provisions of these Articles, except that they shall have:

			(a) a minimum width between wall faces of 700 mm, and
			(b) a minimum clear height over tread nosing or landing of 1 800 mm.
95.	F95	9.8.4.3.	Existing curved or spiral stairs acceptable.
96.	F96	9.8.5.1.(2)	Existing ramps acceptable, where practical.
97.	F97	9.8.7.	Existing handrails acceptable, unless considered unsafe by <i>chief building official</i> .
98.	F98	9.8.8.	Existing <i>guards</i> acceptable, unless considered unsafe by <i>chief building official</i> .
99.	F99	9.8.9.6.(4)	Existing acceptable.
100.	F100	9.9.1.1.	Existing acceptable.
101.	F101	9.9.2.1.(1) to (3)	The following types of <i>exits</i> may also be used:
			(a) connected balconies, which connect across <i>firewalls</i> , or connect to another <i>exit</i> , or with access to grade,
			(b) areas of refuge approved by the <i>chief building official</i> , where fire service rescue is possible, or
			(c) <i>combustible</i> or <i>noncombustible</i> exterior stairways or fire escapes which are protected in accordance with Sentence 3.2.3.13.(2). These may be reconstructed or recreated (as in the case of a <i>heritage building</i> ).
102.	F102	9.9.2.1.(4)	Existing acceptable.
103.	F103	9.9.3.2.	Existing width of <i>exits</i> acceptable.
104.	F104	9.9.3.3.	Existing width of <i>public corridors</i> of not less than 965 mm is acceptable.
105.	F105	9.9.3.4.	Existing clear height of not less than 1 950 mm is acceptable.
106.	F106	9.9.4.2.	30 min <i>fire separation</i> acceptable.
107.	F107	9.9.5.4.	Existing acceptable.
108.	F108	9.9.5.8.	Existing acceptable provided minimum 45 min <i>fire separation</i> and where explosion-resistant <i>construction</i> or venting is provided.
109.	F109	9.9.5.9.	Existing acceptable, provided that the enclosure has a 45 min <i>fire-resistance rating</i> .
110.	F110	9.9.6.3.	Existing door widths are acceptable, provided <i>exit</i> widths comply with C.A. F104.
111.	F111	9.9.6.5.	Existing door swings acceptable. Existing acceptable in <i>public heritage buildings</i> , where approved by <i>chief building official</i> .
112.	F112	9.9.6.6.(1)	Where <i>exit</i> doors open onto a landing, such doors shall not extend beyond the face of the



			first riser.
113.	F113	9.9.6.8.	Existing functionally operable passage or panic hardware acceptable.
114.	F114	9.9.7.4.	Maximum area of existing room or <i>suite</i> does not apply.
115.	F115	9.9.8.2.(1)	Existing travel distance acceptable where <i>floor area</i> is <i>sprinklered</i> and provided <i>fire separations</i> comply with Part 9.
116.	F116	9.9.11.3.	Existing illuminated legible signs are acceptable for <i>exitsigns</i> , if approved by <i>chief building official</i> .
117.	F117	9.10.1.1.	Assemblies required to be of <i>noncombustible construction</i> may be supported by <i>combustible construction</i> having at least the same <i>fire-resistance rating</i> as that supported.
118.	F118	9.10.1.3.(8) to (10)	Existing acceptable subject to C.A.'s F27 and F28.
119.	F119	9.10.3.	<i>Fire-resistance ratings</i> may also be used where they are based on:
			1. HUD Rehabilitation Guidelines, "Guideline on Fire Ratings of Archaic Materials and Assemblies".
			2. DBR Technical Paper No. 194, "Fire Endurance of Protected Steel Columns and Beams".
			3. DBR Technical Paper No. 207, "Fire Endurance of Unit Masonry Walls".
			4. DBR Technical Paper No. 222. Fire Endurance of Light-Framed and Miscellaneous Assemblies".
120.	F120	9.10.5.1.	Existing openings in existing wall or ceiling membranes to remain. Existing openings may be moved to another location in the same wall or ceiling, provided the aggregate area of openings does not increase and are not cumulative, and the existing opening is blocked up to provide the same rating as the existing wall or ceiling assembly.
121.	F121	9.10.6.2.	Existing <i>heavy timber construction</i> acceptable where <i>construction</i> is within 90% of the member sizes listed in Part 3.
122.	F122	9.10.7.	Existing acceptable for <i>heritage buildings</i> , subject to approval of <i>chief building official</i> .
123.	F123	9.10.8.1.	Existing 30 min rating acceptable.

124.	F124	9.10.8.2.	Existing sprinkler systems complying with C.A. F27 and Sentence 3.2.2.17.(1) are acceptable.
125.	F125	9.10.8.3.	Existing acceptable, subject to approval of <i>chief building official</i> .
126.	F126	9.10.8.8.	30 min rating acceptable.
127.	F127	9.10.9.7.; 9.10.9.9.	Existing acceptable in existing <i>fire separations</i> .
128.	F128	9.10.9.10.(1)	Ceiling <i>fire separation</i> need not be <i>fire-resistance rated</i> where sprinklering of <i>fire compartments</i> on both sides of vertical <i>fire separation</i> is provided and where such <i>fire separation</i> is not required to exceed 1 h.
129.	F129	9.10.9.11.(2)	In lieu of the 2 h <i>fire separation</i> , sprinklers may be used in the <i>medium hazard industrial occupancy</i> with a 1 h <i>fireseparation</i> .
130.	F130	9.10.9.13.; 9.10.9.15.(1)	30 min <i>fire separation</i> acceptable.
131.	F131	9.10.10.3.(1)	45 min <i>fire separation</i> acceptable.
132.	F132	9.10.13.1.	Existing functional <i>closures</i> are acceptable subject to C.A. F8.
133.	F133	9.10.13.2.	Existing acceptable.
134.	F134	9.10.13.3.	Existing acceptable, provided that wood door frames are secured with hinge screws going through frame into the stud.
135.	F135	9.10.13.5.	Existing wired glass acceptable.
			Existing transoms or sidelights located in required <i>fire separations</i> may be retained if wired glass, at least 6 mm thick, is securely fixed to a wood frame of at least 50 mm thickness with steel stops. Operable transoms shall be fixed closed.
136.	F136	9.10.13.6.	Existing steel door frames acceptable.
137.	F137	9.10.13.7.	Existing glass block acceptable.
138.	F138	9.10.13.8.	Existing sizes acceptable.
139.	F139	9.10.13.9.	Existing operable latches acceptable.
140.	F140	9.10.13.10.(1)	Existing functionally operable self-closing devices acceptable.
141.	F141	9.10.13.11.	Existing operable self-releasing electromagnetic and fusible link hold-open devices acceptable.
142.	F142	9.10.13.12.	Existing swings acceptable.
143.	F143	9.10.14.4.	Existing windows.
			(a) Existing windows in walls may be relocated to another part of the wall, provided the existing

			opening is blocked up to provide the same fire rating for the wall, and the projection of the new opening, at a right angle to the property line onto another <i>building</i> , lies no closer than 300 mm from a window in such other <i>building</i> , where the “opposite” window is less than 2 400 mm from the opposite new opening, and
			(b) except relocation of units, to be restricted to the same <i>fire compartment</i> and shall conform to the requirements of Article 3.2.3.14. or 9.10.12.3. where applicable, or
			(c) where a <i>building</i> does not satisfy the requirements of Subsection 3.2.3. for the amount of openings facing a yard or space that does not have sufficient <i>limiting distance</i> , such existing openings are allowed to be relocated provided:
			(i) such openings are not increased in size and they are protected with wired glass in steel frames conforming to Sentence 3.1.8.14.(2), or
			(ii) the <i>building</i> is <i>sprinklered</i> .
144.	F144	9.10.16.2.(1)	Where balloon framing is exposed during renovation, <i>fire blocks</i> shall be provided.
145.	F145	9.10.18.	(a) Subject to approval by the <i>chief building official</i> , existing fire alarm system may remain where the fire safety plan (as described in the Fire Code made under the <i>Fire Protection and Prevention Act, 1997</i> ) for the <i>building</i> addresses the intent of Subsection 3.2.4. (i.e. “stage” system, electrical supervision, detection as required, Fire Department connection, and emergency power supply), and
			(b) extension of an existing system must ensure continuity and compatibility, and integrity of the system.
146.	F146	9.10.20.	Existing access acceptable.
147.	F147	9.18.2.	Existing access acceptable.
148.	F148	9.18.3.	Existing vents and ventilation acceptable.
149.	F149	9.19.2.1.	Existing access acceptable.
150.	F150	9.20.2.2.	Used masonry may be reused for patching and filling openings to match adjacent work. Used interior brick may not be used for exterior applications.
151.	F151	9.20.3.	Archaic mortars may be used to match existing

			jointing.
152.	F152	9.20.4.1.	Sound jointing techniques may be employed to match existing archaic joints.
153.	F153	9.20.12.1.	Corbelling may be constructed to match existing or original details, provided that it is structurally adequate for the proposed use.
154.	F154	9.21.	Existing acceptable, provided the products of combustion are safely vented and provided no fire hazard is created.
155.	F155	9.22.1. to 9.22.7.	Sound period materials, designs and techniques may be employed in recreated fireplaces provided no fire hazard is created.
			Existing need not comply with Article 9.22.1.4.
156.	F156	9.23.	Existing acceptable.
157.	F157	9.24.	Existing acceptable.
158.	F158	9.26.	Existing acceptable.
159.	F159	9.27.	Existing acceptable.
160.	F160	9.28.	All replacement or recreation of existing stucco may be compatible with the existing materials and application.
161.	F161	9.29.4.	Existing acceptable. All replacement or recreation of existing plaster may be compatible with the existing materials and application.
162.	F162	9.33.1.2.	Sound, used or antique <i>appliances</i> are acceptable, provided that:
			(a) visual examination shows no excessive weakening by corrosion or other damage,
			(b) no structural parts are missing,
			(c) no cracks are present in the components intended to support the <i>appliance</i> or enclose the fire, and
			(d) loading and ash removal door latches and hinges hold the door closed.
163.	F163	9.37.	Sound used materials shall be acceptable for reuse, subject to the following limitations:
			(a) visual examination shows no excessive weakening by holes, notches, nail splits or other damage, and
			(b) logs have not been subjected to termite infestation.

O. Reg. 332/12, Division B, Part 11; O. Reg. 151/13, ss. 33-37; O. Reg. 361/13, ss. 97-113; O. Reg. 368/13, ss. 38-42; O. Reg. 191/14, ss. 129-145; O. Reg. 139/17, ss. 138-143.